



David Bennett
Vice President, Regulatory Affairs
And General Counsel

FortisBC Inc.
Regulatory Affairs Department
1290 Esplanade Box 130
Trail BC V1R 4L4
Ph: 250 717 0853
regulatory@fortisbc.com
www.fortisbc.com

August 28, 2007

Via Email
Original via mail

Mr. R. J. Pellatt
Commission Secretary
BC Utilities Commission
Sixth Floor, 900 Howe Street, Box 250
Vancouver, BC V6Z 2N3

Dear Mr. Pellatt:

Re: An Application for a CPCN for the Distribution Substation Automation Program

Further to FortisBC Inc.'s 2005 System Development Plan and BC Utilities Commission Order G-52-05 regarding the above noted project, please find enclosed for filing twenty copies of FortisBC's Application. In the previously referenced decision the Commission requested that a CPCN be filed for this project and noted:

"Distribution Substation Automation: This [CPCN] is required because it is not clear to the Commission Panel what the possible risks and benefits are associated with the project, what precedent it may set for future projects, and if FortisBC is selecting the appropriate technology."

FortisBC feels that the attached application examines all of these areas and provides a clear justification for this program.

Sincerely,

David Bennett
Vice President, Regulatory Affairs
and General Counsel



**AN APPLICATION FOR A
CERTIFICATE OF PUBLIC CONVENIENCE AND NECESSITY**

DISTRIBUTION SUBSTATION AUTOMATION PROGRAM

AUGUST 28, 2007

FORTISBC INC.

TABLE OF CONTENTS

3	EXECUTIVE SUMMARY	2
4	1. THE APPLICATION	4
5	2. THE APPLICANT	4
6	2.1. NAME, ADDRESS, AND NATURE OF BUSINESS.....	4
7	2.2. FINANCIAL AND TECHNICAL CAPACITY.....	4
8	2.3. CONTACT PERSONS.....	5
9	3. PROJECT DESCRIPTION	6
10	3.1. PRESENT DESIGN PRACTICES AND EQUIPMENT STANDARDS.....	6
11	3.2. STATIONS EXCLUDED.....	12
12	3.3. INDIVIDUAL SCOPES OF WORK.....	14
13	3.4. PROJECT SCHEDULE.....	17
14	3.5. PROJECT COST	18
15	4. PROJECT JUSTIFICATION.....	22
16	4.1. REMOTE VISIBILITY	24
17	4.2. LOAD FORECASTING	25
18	4.3. MAINTENANCE PLANNING	25
19	4.4. REVENUE PROTECTION AND LOSS ANALYSIS.....	26
20	4.5. SAFETY	28
21	4.6. OPERATING AUTHORITY	29
22	4.7. REMOTE OPERATION	30
23	4.8. METERING	33
24	4.9. "INTELLIGENT" RELAYING.....	33
25	4.10. REDUCED MAINTENANCE COSTS	36
26	4.11. SYSTEM INTEGRITY AND SECURITY	36
27	4.12. CENTRAL DATABASE	37
28	5. PUBLIC CONSULTATION.....	37
29	6. OTHER APPLICATIONS AND APPROVALS.....	38
30	APPENDIX 1 – REVENUE REQUIREMENTS ANALYSIS.....	39

1 **EXECUTIVE SUMMARY**

2 The Program includes the installation of automated systems in distribution
3 substations to gather and analyze data so that decisions can be made more quickly
4 and effectively. It is a multi-year staged Program that focuses on reducing
5 operational costs, preventing power outages and restoring power more quickly when
6 there is a failure, as well as improving the levels of safety to employees and the
7 public. The Program will commence in 2007 at a capital cost of \$6.38 million to be
8 completed by the end of 2011. The Program net present value (NPV) is estimated at
9 \$1.30 million with a one-time equivalent rate impact of 0.05%.

10

11 The term “automation” can imply a range of complexity. Systems can consist of
12 relatively simple data logging and monitoring, or they can extend to highly automated
13 schemes that can provide automatic restoration of customer load following system
14 outages. This Application proposes implementing solutions for monitoring and
15 control of the system as opposed to the more complex load restoration and auto-
16 transfer schemes. A standard package of protection, monitoring and data collection
17 equipment and system has been developed by FortisBC and is being applied to all
18 new substation construction. The scope of this Application involves the installation of
19 these systems to substations that are not currently slated for major upgrade or
20 replacement in the foreseeable future.

21

22 This Program broadens the integration and use of remote monitoring and control to
23 distribution level substations, including the quality monitoring of lines, transformers
24 and feeders, fault recording and locating, and equipment condition monitoring. It will
25 provide common communication mechanisms for gathering, storing, accessing and
26 analyzing the accumulated data. The Program includes the development of a central
27 data repository, individual equipment installation projects in appropriate substations,
28 and an emergency backup plan.

29

30 This Program produces many specific benefits. Several will be realized immediately
31 while others will come to fruition as data analysis occurs related to ongoing

FortisBC Inc.
Distribution Substation Automation Program

1 maintenance and capital replacement projects. One of the immediate benefits is the
2 ability to operate switches remotely, allowing work to commence more quickly, as
3 well as enabling the restoration of power more quickly during conditions of unplanned
4 outage. Another example is the ability to meter individual distribution feeder loads,
5 allowing planners to accurately determine electrical consumption at frequent
6 intervals. This information can be used to move load between feeders and increase
7 the efficiency of plant additions, as well as plan for new feeders and substations on a
8 "just in time" basis.

9

10 Longer term benefits include more targeted maintenance planning. As an example,
11 power transformer life can be more precisely measured over time, and new
12 transformation can be planned and installed when the life of the unit is about to
13 expire, as opposed to merely using peak load as the replacement indicator. The
14 effect of this may be to extend the life of some transformers without incurring any
15 greater system risk.

16

17 A list of the benefits associated with this Program is described in detail in this
18 Application.

19

20 As described herein, savings are forecast to be realized in future operating and
21 capital budgets as well as the potential deferral of some capital expenditures.

22

23 Utilities around the globe have recognized the benefits of these automation systems,
24 which have lead to the development of a new industry standard. FortisBC has
25 applied this approach in recently constructed substations and has received the
26 commensurate benefits. To extract the maximum benefits in terms of operating
27 costs, outage reduction and safety, this Application proposes to install automation
28 systems in older substations that are not slated for major upgrade or replacement
29 and that will form a significant part of the power system for years to come.

1 **1. THE APPLICATION**

2 FortisBC hereby applies to the British Columbia Utilities Commission, (the
3 “Commission”) pursuant to Sections 45 and 46 of the Utilities Commission Act,
4 for a Certificate of Public Convenience and Necessity (the “Application”) for
5 the Distribution Substation Automation Program (the “Program”) at a cost of
6 approximately \$6.38 million.

7

8 This Program is required to enable improved substation data collection,
9 remote equipment operation, improved distribution reliability, and enhanced
10 power system planning and safety.

11

12 The Program consists of installing automated control and data acquisition
13 systems in 28 existing substations. All equipment design and operation is
14 consistent with the equipment currently being installed in new substations in
15 the FortisBC service territory.

16 **2. THE APPLICANT**

17 **2.1. Name, Address, and Nature of Business**

18 FortisBC Inc.
19 Landmark IV
20 Fifth Floor, 1628 Dickson Avenue
21 Kelowna, BC V1Y 9X1

22

23 FortisBC is an investor-owned, regulated utility engaged in the business of
24 generation, transmission, distribution and sale of electricity in the southern
25 interior of British Columbia.

26 **2.2. Financial and Technical Capacity**

27 FortisBC is an integrated utility serving over 150,000 customers directly and
28 indirectly. It was incorporated in 1897 and is regulated under the Utilities
29 Commission Act of British Columbia. The Company owns assets of

FortisBC Inc.
Distribution Substation Automation Program

1 approximately \$670 million, including four hydroelectric generating plants with
2 a combined capacity of 235 megawatts and approximately 6,400 kilometres of
3 transmission and distribution power lines for the delivery of electricity to major
4 load centers and customers in its service area. FortisBC employs
5 approximately 500 full time and part time people. FortisBC has been engaged
6 in the construction and operation of facilities of the type described above since
7 its inception in 1897.

8 **2.3. Contact Persons**

9 Regulatory/Legal Contact:

10 David Bennett
11 Vice President, Regulatory Affairs and General Counsel
12 Regulatory Affairs Department
13 1290 Esplanade, Box 130
14 Trail, BC V1R 4L4
15 Phone (250) 717 0853 Fax (866) 605 9431

16
17 Technical Contact:

18 Paul Chernikhowsky, P. Eng.
19 Chief Planning Engineer
20 2850 Benvoulin Road
21 Kelowna, BC V1W 2E3
22 Phone (250) 717 0894 Fax (866) 461 0987

1 **3. PROJECT DESCRIPTION**

2 Substation automation is an all inclusive term used to describe the integration
3 and use of system information from substations for the remote monitoring and
4 control of substation equipment, the quality¹ monitoring of lines, transformers
5 and feeders, fault recording and locating, equipment condition monitoring,
6 automatic closed loop switching, as well as common communications
7 mechanisms for gathering, storing, accessing and analyzing the resulting data.
8 Resulting benefits are improvements in system performance, productivity,
9 safety and economics.

10 This Program will ultimately enable remote operating and automated load and
11 quality metering of all substations in the system. This will aid in averting
12 equipment overloads and associated damage. The automation component
13 will enable rapid remote circuit reconfiguration, thereby reducing outage times
14 and reducing operating expenses associated with sending out crews to
15 perform manual adjustments and switching. Equipment use will be better
16 monitored, which will aid in the effective deployment of maintenance resources
17 to the equipment experiencing the greatest loading.

19 The Program requires the installation of “intelligent” electronic devices at many
20 substations for data capture, as well as building a communications network to
21 substations with no existing remote communications, and building an
22 informational database to accept the data.

24 **3.1. Present Design Practices and Equipment Standards**

25 Station automation system designs are appropriate for the size and
26 importance of the station. For example, all of the systems that would be
27 installed at a major transmission station would not necessarily be installed at a
28 small rural substation. FortisBC has developed, through experience and

¹ Quality in this context refers to both “power quality” (such as voltage sags/swells, harmonics, etc.) as well as “service reliability” (such as the duration and number of outages).

1 industry consultation, a “suite” of automation equipment that provides the
2 benefits desired without paying for unnecessary functionality.

3
4 The listed items, complete with their purpose, comprise the major automation
5 systems that FortisBC is currently applying to new construction and is
6 intending to apply to the legacy substations identified in this Application. It is
7 important to note that:

- 8 a. The technology cited is not “cutting edge” or beta version. It is highly
9 functional and has been market available long enough to have been
10 reviewed and tested by many utilities;
11 b. FortisBC has installed this technology in other substations as part of recent
12 upgrades. The equipment has been successful in enabling the desired
13 outcomes. No untried technology is proposed as part of this Program.

14 **3.1.1. Protection Relays**

15 These microprocessor-based devices are highly sophisticated and allow for
16 programmable logic to be incorporated. The units are very economical as
17 compared to past technologies where it was necessary to install a large
18 number of separate components. Essentially, the logic and monitoring
19 capabilities are provided “free” along with the required protection elements.
20 This allows the implementation of schemes that would not have previously
21 been practical or affordable.

22
23 FortisBC has standardized on a single manufacturer for protection relaying
24 equipment which reduces costs by reducing the number and variety of spare
25 devices that must be maintained in inventory. Similarly, this common platform
26 reduces training costs as there are few devices for technicians and engineers
27 to become familiar with and ensures that the technicians have a good and
28 ongoing understanding of the equipment as it is worked with routinely.

29
30 **Equipment Standard:** A selection of standard protection relays from
31 Schweitzer Engineering Laboratories, Pullman WA, USA

1 **3.1.2. Power-Quality Monitoring**

2 These devices are becoming increasingly important as the FortisBC customer
3 load continues to grow. In order to make intelligent decisions regarding
4 system expansion it is necessary to know how much power is being delivered
5 to any given location. Old-style electromechanical metering provides minimal
6 information and hinders the planners' ability for optimal matching of system
7 growth to load growth. Customers are also increasingly sensitive to power-
8 quality disturbances that would have gone unnoticed in the past. These
9 devices allow the tracking and the resultant resolution of power quality
10 problems much more quickly than would otherwise be possible.

11
12 The meters are linked to an existing central monitoring and logging system
13 which captures and stores the information for later use in a number of
14 applications, such as power system load modeling. The database server is
15 designed for high availability and has multiple central processing units
16 ("CPUs"), hard drives and power supplies. The database contents are backed
17 up nightly onto tape drives; these tape archives are then stored offsite for
18 disaster survival.

19
20 **Equipment Standard:** Two standard meters from Schneider Electric (Power
21 Measurement Ltd.), Victoria BC

22 **3.1.3. Digital Fault Recorders ("DFRs")**

23 DFRs are only installed at major terminal stations and are used to provide a
24 complete record of station conditions when a fault or electrical disturbance
25 occurs. These devices supplement the power quality monitoring and
26 protection relaying. In general, these devices are not installed in distribution
27 substations; however, a sufficient subset of their functionality is available in the
28 protection and metering equipment discussed in the previous sections. This
29 level of functionality is considered adequate for distribution-class substations.

1 **3.1.4. Communications**

2 A number of systems are used within FortisBC for inter-substation
3 communications, dictated by station age and criticality within the power
4 system. The preferred medium is fibre-optic cable due to its high reliability
5 and capacity.

6

7 Included below are examples of the communications infrastructure that is
8 currently in use or accepted by FortisBC, and is the proposal that forms the
9 scope of this Program:

- 10 • Fibre-optic multiplexing equipment supplied by GE Multilin, Burnaby
11 BC. This equipment is typically installed at larger substations and
12 generating plants and provides very high bandwidth between these
13 locations. This system has multiple levels of redundancy and thus has
14 extremely high reliability. This is important as this system is also used
15 to convey relay tele-protection communications between locations.
16 Delays or failures in this signaling can directly affect the reliability and
17 operation of the power system.
- 18 • Licensed 950 MHz digital wireless communications has been installed
19 in Penticton and Kelowna to provide communications to the substations
20 in these areas. This equipment has been supplied by GE Microwave
21 Data Systems, Rochester NY, USA. This system is used for critical
22 data such as System Control and Data Acquisition (“SCADA”)
23 communications. At the present time, unlicensed systems are not
24 considered secure or reliable enough for multi-point SCADA data links.
- 25 • Satellite communications supplied by TSAT of Norway has been
26 successfully deployed at a number of remote substation locations. This
27 system provides a low-bandwidth communications link to the FortisBC
28 System Control Center. This equipment is ideal for small stations that
29 have low data exchange requirements. It can also provide
30 communications to isolated areas where other facilities are either not
31 available or would be cost prohibitive to install.

- Unlicensed 900 MHz digital wireless communications has been installed in Penticton and Kelowna to provide network communications to the substations in these areas. This equipment has been supplied by GE Microwave Data Systems, Rochester NY, USA. As these systems are unlicensed (and may thus be susceptible to interference by other users), these radio links are only used to provide non-critical corporate wide-area network access to substation meters and relays. Unlicensed systems are also used in limited cases for point-to-point SCADA communications.
 - POTS (“plain old telephone service”) dialup lines are installed at numerous locations to provide remote access to relays and meters. This is acceptable where other methods of communication would be cost prohibitive or unjustifiable based on data bandwidth requirements. Since these connections are only established on an “as needed” basis, they are not useful for the real-time continuously available data circuits required for SCADA purposes.
 - Cellular data and telephone leased lines are installed in locations where SCADA communication is required, but no alternate communication infrastructure is available. These circuits have good availability and provide a permanent connection to the remote location. However, leased lines have a relatively high on-going monthly cost and this provides a strong motivation to install FortisBC owned and operated infrastructure when/where possible.

3.1.5. Stations Included in the Program Scope

Those stations that will remain as part of the power system and are not currently slated for major upgrade in the next few years form the scope of the Program, and are identified in Table 1. The general type of equipment required, a cost estimate and a priority ranking for each location is also shown. The priority is based on the benefits to be derived. Considerations include rate of growth in an area (feeder metering benefit), the distance from a staffed

FortisBC Inc.
Distribution Substation Automation Program

1 headquarters (remote tagging benefit), the overall absence (or existence) of
2 current automation and so on. The status for each station indicates the
3 functionality of the station at the time of submission of this Application,
4 including previously approved capital improvements that are scheduled for
5 2007/2008 installation.

6

7

TABLE 1

Priority	Abr	Station Name	Metering	Metering Comm.	Relaying	RTU	Comm. Processor	Tagging	Construction Year	Cost (\$000s)
1	DGB	Bell Terminal						X	2008	24
1	CAS	Castlegar	X		X	X	X	X	2008	345
1	DUC	Duck Lake	X				X	X	2008	131
1	FRU	Fruitvale					X		2008	42
1	GLE	Glenmore			X			X	2008	125
1	HOL	Hollywood			X		X	X	2008	375
1	KER	Keremeos					X	X	2008	54
1	SUM	Summerland			X	X			2008	89
2	BEP	Beaver Park				X	X		2009	152
2	BLU	Blueberry		X		X	X		2009	140
2	OKM	OK Mission			X		X	X	2009	383
2	OSO	Osoyoos			X			X	2009	122
2	PLA	Playmor				X	X	X	2009	183
2	SAU	Saucier	X						2009	37
2	VAL	Valhalla				X			2009	91
2	WES	Westminster	X	X		X			2009	140
3	CHR	Christina Lake	X	X		X			2010	180
3	GLM	Glenmerry				X	X	X	2010	186
3	HED	Hedley	X		X	X	X	X	2010	348
3	SAL	Salmo				X	X		2010	155
3	TRC	Trout Creek	X	X		X			2010	223
3	WEB	West Bench	X	X	X	X	X		2010	286
4	HUT	Huth	X	X				X	2011	190
4	PAS	Passmore	X	X		X			2011	139
4	SEX	Sexsmith			X		X	X	2011	272
4	SLO	Slocan City				X			2011	95
4	STC	Stoney Creek	X	X	X	X	X		2011	291
4	TAR	Tarrys	X	X	X	X	X	X	2011	348
8	Subtotal:									5,146

9

Note: "X = work required"

1 **3.2. Stations Excluded**

2 As previously discussed, all new stations will be built with standardized
3 FortisBC station automation systems. The costs of these systems are
4 included in the individual project budgets and therefore these stations are not
5 included within the scope of this Application.

6

7 These new distribution stations include:

- 8 a. COT – Cottonwood Substation (south of Nelson)
- 9 b. AWA – Arawana Substation (Naramata)
- 10 c. KET – Kettle Valley Substation (east of Rock Creek)
- 11 d. NKM – Nk'Mip Substation (east Osoyoos)
- 12 e. BWS – Big White Substation (Big White Village)
- 13 f. ELL – Ellison Substation (north Kelowna)
- 14 g. BLK – Black Mountain Substation (east Kelowna)
- 15 h. OOT – Ootischenia Substation (east of Castlegar)

16

17 As well, there are a number of older substations that will be retired in the near
18 future and therefore will not be included in this Program. These are:

- 19 a. NAR – Naramata Substation (to be replaced by Arawana in another
20 location)
- 21 b. WYN – Wynndel Substation (replaced by new distribution facilities at AA
22 Lambert)
- 23 c. ROC – Rock Creek Substation (to be replaced by Kettle Valley)
- 24 d. MID – Midway Substation (to be replaced by Kettle Valley)
- 25 e. GRE – Greenwood Substation (to be replaced by Kettle Valley)
- 26 f. PAT – Paterson Substation (retired as part of the Rossland voltage
27 conversion)
- 28 g. WHI – Whitewater Substation (to be replaced by Cottonwood
29 Substation)
- 30 h. YMR – Ymir Substation (to be replaced by Cottonwood Substation)

31

FortisBC Inc.
Distribution Substation Automation Program

1 Finally, there are a number of stations that are under review by FortisBC
2 Planning either for major station reconstruction or replacement. Since the
3 future of these sites is unclear they are excluded from this program. If it is
4 determined that a substation rebuild is appropriate, then the costs of adding
5 automation systems would be included in a future capital plan or CPCN
6 application.

7

8 These stations include:

- 9 a. RUC – Ruckles Substation (to be upgraded in the future – this site will
10 be included in a future Capital Plan submission)
- 11 b. KAL/OKF – Kaleden and OK Falls Substations (these may either be rebuilt
12 or combined as a single new substation).

13

1 3.3. Individual Scopes of Work

Table 2 describes the high-level scope of work required for the individual substations identified in Table 1. Upon approval of the Program, detailed scoping and estimating would be carried out for each location.

TABLE 2

ABR	Station Name	Scope of Work
BEP	Beaver Park Substation	Install communications processor Upgrade station RTU
BLU	Blueberry Substation	Install communications processor Install station RTU Connect existing meter for transformer monitoring Install communications to System Control Center Install dial-up phone line for access to relays and meters
CAS	Castlegar Substation	Upgrade feeder relaying Install per-feeder metering Connect existing meter for transformer monitoring Install communications processor Install remote tagging switches Install station RTU Install communications to System Control Center
CHR	Christina Lake Substation	Install feeder metering Install station mini RTU Install communications to System Control Center Install dial-up phone line for access to meters
DGB	Bell Terminal	Install remote tagging switches
DUC	Duck Lake Substation	Install transformer monitoring Upgrade feeder metering Install communications processor Install remote tagging switches
FRU	Fruitvale Substation	Install communications processor
GLE	Glenmore Substation	Upgrade feeder protection Install transformer monitoring Install remote tagging switches
GLM	Glenmerry Substation	Install remote tagging switches Install communications processor Install station RTU Install communications to System Control Center
HED	Hedley Substation	Upgrade feeder relaying Install per-feeder metering Install transformer monitoring Install communications processor Install remote tagging switches Install station RTU Install communications to System Control Center

FortisBC Inc.
Distribution Substation Automation Program

1

TABLE 2 CONT'D

2

ABR	Station Name	Scope of Work
HOL	Hollywood Substation	Upgrade feeder protection Install communications processor Install remote tagging switches
HUT	Huth Substation	Upgrade feeder metering Install communications processor Install remote tagging switches Install transformer monitoring Install wireless network communications
KER	Keremeos Substation	Install transformer monitoring Install remote tagging switches Install communications processor
OKM	OK Mission Substation	Upgrade feeder protection Install remote tagging switches Install communications processor
OSO	Osoyoos Substation	Upgrade feeder protection Install remote tagging switches
PAS	Passmore Substation	Install feeder metering Install station mini RTU Install communications to System Control Center Install dial-up phone line for access to meters
PLA	Playmor Substation	Install station mini RTU Install communications to System Control Center Install communications processor
SAL	Salmo Substation	Install communications processor Install station RTU Install communications to System Control Center
SAU	Saucier Substation	Install transformer monitoring
SEX	Sexsmith Substation	Upgrade feeder relaying Install communications processor Install remote tagging switches
SLO	Slocan City Substation	Install station mini RTU Install communications to System Control Center
STC	Stoney Creek Substation	Upgrade feeder relaying Install feeder metering Install transformer monitoring Install station mini RTU Install communications to System Control Center Install dial-up phone line for access to meters
SUM	Summerland Substation	Install transformer monitoring Install station mini RTU Install communications to System Control Center

3

1

TABLE 2 CONT'D

ABR	Station Name	Scope of Work
TAR	Tarrys Substation	Upgrade feeder relaying Install per-feeder metering Install transformer monitoring Install communications processor Install remote tagging switches Install station RTU Install communications to System Control Center Install dial-up phone line for access to relays and meters
TRC	Trout Creek Substation	Install feeder metering Install transformer monitoring Install station mini RTU Install communications to System Control Center Install dial-up phone line for access to meters
VAL	Valhalla Substation	Install station mini RTU Install communications to System Control Center
WEB	West Bench Substation	Install feeder metering Upgrade feeder relaying Install communications processor Install station RTU Install communications to System Control Center Install dial-up phone line for access to relays and meters
WES	Westminster Substation	Install transformer monitoring Install station RTU Install communications to System Control Center Install dial-up phone line for access to relays and meters

2

1 **3.4. Project Schedule**

2 Program implementation will occur over a five year time period.

3

4 In 2007 the following activities are planned to take place:

5 Pre-regulatory approval:

- 6 • Preliminary (+/-25%) engineering estimating
7 • CPCN preparation and submission

8 Post-regulatory approval:

- 9 • Detailed scoping and estimating (+/-10%)
10 • Material takeoffs and vendor negotiations
11 • Initial engineering design and procurement.

12

13 The relative priority ranking scale described in Table 1 also represents the
14 year of implementation. On-site construction will commence in 2008 with
15 completion in 2011. The construction schedule is summarized in Table 3.

16

17 **TABLE 3**

Year	Region	Number of Stations
2008	Kootenays	2
	Okanagan	5
2009	Kootenays	4
	Okanagan	4
2010	Kootenays	3
	Okanagan	3
2011	Kootenays	3
	Okanagan	4
Total		28

1 **3.5. Project Cost**

2 The program is composed of two main components:

- 3 1. Equipment installations within substation sites, and
4 2. Data collection and archiving server hardware and software.

5
6 As described in Table 4 below, the total cost of the Program is estimated to be
7 \$6.38 million (+/-25%) with expenditures occurring over a five year period.

8 This figure is in as-spent dollars and includes a 10% contingency allowance.

9 This estimate compares favourably with the \$5.8 million cost which was
10 originally submitted in the FortisBC 2005 System Development Plan (as that
11 value was in 2004 dollars). The apparent increase is due to inflation since that
12 time and over the installation period of the Program.

13
14 The Program NPV is estimated at \$1.30 million with a one-time equivalent rate
15 impact of 0.05%. A detailed calculation of the revenue requirements is
16 presented in Appendix 1. For the purposes of this application the revenue
17 requirements calculation has been carried out to 20 years as much of the
18 equipment to be installed by the program is expected to reach this lifespan.

19
20 In calculating the Program NPV, an "Annual Cost Reduction" from Table 5 has
21 been applied as a reduction to future operating and capital costs. This value is
22 the estimated yearly savings that are expected to be achieved on completion
23 of the Program. An average of the "Estimated Minimum" and "Estimated
24 Maximum" values has been used in the calculation as an assumption. Thus, a
25 value of \$590,000 is used for the initial savings starting in 2011. This cost
26 reduction has been apportioned as follows: 20% of the savings (\$118,000) to
27 a reduction in operating costs (line 56 in Appendix 1) and 80% of the savings
28 (\$472,000) to a reduction in future capital costs (line 48 in Appendix 1). This
29 allocation was chosen as the majority of the quantifiable program benefits due
30 to remote operation of switching devices will be attributed to future capital
31 projects. This is true even for forced outages; for widespread outages where

FortisBC Inc.
Distribution Substation Automation Program

1 the benefits of automation would be most applicable, the outage costs would
2 be capitalized due to the large amount of power system infrastructure that is
3 replaced.

4

5 Note that the financial benefits listed in Table 5 are partially offset by additional
6 operating costs (mainly due to leased-line and communications monthly
7 charges) that will be required for some installations. FortisBC attempts to
8 minimize the use of leased communications and prefers to install utility-owned
9 and operated infrastructure where it is possible and cost effective.

FortisBC Inc.
Distribution Substation Automation Program

1
2

TABLE 4

Installation / Substations	2007	2008	2009	2010	2011
	(\$000s)				
Bell Terminal		24			
Castlegar		345			
Duck Lake		131			
Fruitvale		42			
Glenmore		125			
Hollywood		375			
Keremeos		54			
Summerland		89			
Beaver Park			152		
Blueberry			140		
OK Mission			383		
Osoyoos			122		
Playmor			183		
Saucier			37		
Valhalla			91		
Westminster			140		
Christina Lake				180	
Glenmerry				186	
Hedley				348	
Salmo				155	
Trout Creek				223	
West Bench				286	
Huth					190
Passmore					139
Sexsmith					272
Slocan City					95
Stoney Creek					291
Tarrys					348

3

FortisBC Inc.
Distribution Substation Automation Program

1
2
3

TABLE 4 CON'T

Installation / Substations	2007	2008	2009	2010	2011
	(\$000s)				
Additional costs:					
Estimating/Engineering/Procurement	462	0	0	0	0
Data server hardware & software	0	140	33	0	0
Contingency (10%)	46	132	128	138	134
AFUDC	18	0	0	0	0
Total Annual Capital Cost	526	1,456	1,409	1,516	1,470
Total Capital Cost	6,378				
Net Present Value	1,301				
One Time Rate Impact	0.05%				

4

1 **4. PROJECT JUSTIFICATION**

2 The ultimate goal of implementing the Substation Automation Program is to
3 improve employee and public safety, power quality and reliability as seen by
4 the customers. In this section, specific examples are provided to demonstrate
5 the actual improvements and resulting benefits. These benefits are both
6 immediate and long term and are summarized in Table 5 and described in
7 detail in this Section.

8

9

FortisBC Inc.
Distribution Substation Automation Program

1

TABLE 5 - PROGRAM BENEFITS

Section	Category	Cost Savings Quantifiable (within 25% accuracy)?	Annual Cost Reduction (estimated minimum)	Annual Cost Reduction (estimated maximum)	Other Cost Comments	Reliability Enhanced?	General Comments
4.1	Remote Visibility	N				Outages can be reduced in length, and potential future outage causes better identified	
4.2	Load Forecasting	N			Increased knowledge about the feeder loading profile allows load balancing both intra- and interfeeder, reducing the possibility of premature capital expenditure for new feeders.	Feeder loading data allows prudent load transfers based on time of day, reducing the stress on highly loaded feeders	
4.3	Maintenance Planning	Y	\$40,000	\$80,000			Based on reduced frequency of formal substation meter reading.
4.4	Revenue Protection or Loss Analysis	N			Partial recovery of an estimated annual \$2.4 million in power losses.		Recovery potential increases with the collection and analysis of load data.
4.5	Safety	N				Reduced response times to troubleshoot substation problems.	Advanced indication of critical substation alarms.
4.6	Operating Authority	N		\$100,000	Field crews available for restoration efforts rather than PIC duties.		
4.7	Remote Operation	Y	\$397,000	\$397,000		Conservatively eliminate 9,000 customer outage hours per year	
4.8	Metering	N				Load balancing and load transfer between feeders will reduce the chance of distribution outages due to feeder overload.	
4.9	Intelligent Relaying	Y	\$45,000	\$120,000	Potential for future capital cost deferral based on the use of transformer temperature tracking technology as opposed to nameplate capacity exceedance only.		
4.10	Reduced maintenance	N			Routine maintenance of electromechanical relays will no longer be required.	Proactive warning of relay failures can prevent larger outages if backup protection is required to operate in place of primary protection.	
4.11	System Security	N					Supports the functions listed above.
4.12	Central Database	N					Supports the functions listed above.
	Totals		\$482,000	\$697,000			

2

1 **4.1. Remote Visibility**

2 To effectively determine the required capacity at a supply point it is necessary to
3 have accurate real-time information on system loading at that point. In the case
4 of a distribution substation, ideally it would be possible to have load information
5 (both real and reactive power) for each distribution feeder. As well, information
6 on the station ambient temperature as well as the power transformer oil and
7 winding temperatures should be provided. Together, this information gives the
8 complete load profile.

9
10 In addition, the system reliability indicators that are affected are both the duration
11 and frequency of outages. Older equipment provides little information post-fault
12 to assist with locating the cause of a fault. This results in unnecessarily long
13 outages as feeder problems are traced. This involves electricians and power line
14 technicians ("PLTs") spending time at the station and along feeder circuits,
15 searching for the problem. In the absence of specific fault related data, the
16 investigation may require several tradesmen and technicians to conduct
17 equipment tests as well as look for physical causes. This not only incurs
18 unnecessary cost, but takes the skilled workers away from other more proactive
19 work. This exposes the customer to both increased cost and longer and/or
20 avoidable outages.

21
22 Substation protection equipment failures have also been known to cause outages
23 where no actual problem existed. For example, in 2002 Recreation Transformer
24 1 tripped five times due to a wiring failure in the transformer protection. Tracing
25 the source of the misoperation was difficult due to the lack of recording
26 equipment at this location. Similar incidents occurred with Transformer 3 at FA
27 Lee Terminal station in 2003 and Transformer 1 at AA Lambert Terminal station
28 in 1999. Once monitoring equipment and upgraded protection was installed, the
29 problems were quickly found and corrected. Installing this equipment at other
30 locations will help reduce or prevent future outages.

1 **4.2. Load Forecasting**

2 Detailed and accurate load information is required to make correct network
3 planning decisions. With historical station load and load factor data information
4 available, it is possible to deploy capital expenditures in a strategic fashion.
5 Where electronic metering is not deployed, previous area and station loading
6 was estimated based on the peak demand reading from the station ammeters,
7 installed either on the transformer or each feeder. Unfortunately, this reading is
8 simply a snapshot in time – it provides no information regarding when the peak
9 was reached, how long it lasted, or what load transfers may be impacting the
10 levels. Modern meters have the capability to record data on a periodic interval.
11 From this data an accurate load profile and load factor can be calculated. This is
12 critical to ensure that required capacity is installed where and when it is required.

13 **4.3. Maintenance Planning**

14 In order to make correct decisions regarding the appropriate amount of system
15 maintenance, it is necessary to understand the past performance of the system.
16 Previously, maintenance schedules were usually calendar driven and did not
17 necessarily account for the service duty of individual pieces of equipment. For
18 example, all high-voltage oil circuit breakers might be overhauled every five
19 years. This does not account for the number of operations or actual current
20 interrupted by the breakers. Thus, in some cases, a breaker may have been
21 “over-maintained” for its service duty (i.e. low operations count, or low fault level)
22 while other breakers that saw more severe service should have actually been
23 maintained more frequently. An automated data-collection platform can greatly
24 assist in making effective maintenance decisions.

25
26 Critical information that directs the maintenance schedule includes:

- 27 • Circuit breaker operations count;
28 • Circuit breaker cumulative interrupted current;
29 • Peak and/or demand current values;
30 • Tap changer operations count;

- 1 • Transformer oil and winding temperatures;
2 • Ambient temperature.

3
4 Historically, this information has been collected on a monthly basis for each
5 substation by dispatching a substation electrician to read the electromechanical
6 station meters. As previously described, many of these values are monthly high
7 readings and do not offer a chronology of events.

8
9 There is also a cost associated with this monthly reading. Automation will not
10 only allow a greater range of information to be created, the labour and data entry
11 costs associated with these monthly checks will also be largely avoided. As an
12 example of savings, the 2005 total for this activity was approximately \$120,000.
13 With the implementation of this Program, it is expected that these inspections
14 could be reduced to bimonthly or quarterly, reducing the annual inspection cost
15 by between \$40,000 and \$80,000 annually.

16
17 FortisBC has recently purchased and installed a new Computerized Maintenance
18 Management System (“CMMS”). This system can directly link to the station
19 automation central database to automatically trigger maintenance work orders or
20 email warnings if unusual conditions are detected. Preventive action can then be
21 taken to reduce the likelihood of premature loss of equipment life.

22 **4.4. Revenue Protection and Loss Analysis**

23 All electric utilities encounter system losses. Losses labelled as technical are:
24 • Transformer resistance and magnetizing losses;
25 • Transmission line resistance losses; and
26 • Distribution line resistance losses.

1 Non-technical/commercial losses are:

- 2 • Customer installations, such as unbilled streetlights or traffic lights;
- 3 • Billing errors; and
- 4 • Power theft.

5
6 System losses are replaced either by increasing local generation where possible,
7 or by purchasing more bulk power through supply contracts, both of which are
8 quantifiable non-recoverable costs, so any effort to reduce these losses has an
9 immediate and positive effect.

10
11 While some of these losses are unavoidable (all power transmission lines exhibit
12 resistance losses), they can be minimized by optimizing system design. For
13 example, transmission line losses can be minimized by increasing the operating
14 voltage or using larger conductors with lower resistance or reconfiguring the
15 system flows. Present day transformer designs are highly efficient and typically
16 have lower losses than older transformers. As new facilities are planned,
17 designed and constructed, these factors are considered. However, replacing
18 transformers or changing system voltages involves capital cost expenditures that
19 must be justifiable including the value of the reduced losses they create.

20
21 Determining losses, either in real-time or historically, is time consuming and
22 complex without adequate data for purposes of analysis. It requires the
23 knowledge of the total system production (total local generation plus imports) and
24 the total customer load at any point in time. If these are known the two can be
25 subtracted to determine the loss value. In the FortisBC system the total system
26 production is known to a high degree of accuracy. Both the instantaneous and
27 hourly energy output of all generating units is known and delivered to the System
28 Control Center. The same is true for all of the high voltage tie-lines to other
29 utilities. The energy delivered to metered loads can be identified "after the fact"
30 from the billing system, however, the magnitude of losses within various sections

of the transmission and distribution system in many cases must be estimated by system modelling. Additional load monitoring would provide a higher degree of accuracy to these estimates enabling more efficient operation of the system and subsequent reduction of losses.

FortisBC total system losses are estimated to be 9.5%, while system modelling has calculated technical losses to be in the area of 9%. Using the average annual load, the total system average losses are in the order of 38 MW. Considering a single MW can result in a power purchase cost of up to \$300,000 annually, there is significant potential for cost savings by reducing both unmetered and technical losses through more accurate information. It is not unreasonable to expect with better data that at least 1-2% of these system losses could be targeted and reduced if not even fully eliminated. With each 1% of loss reduction equivalent to approximately 4MW of load loss, the potential financial benefits are as high as \$2.4M annually.

4.5. Safety

The systems to be installed in this Program enable the System Control Center to gain visibility of critical alarms in real-time. This provides an immediate indication that the system is not operating as required; personnel can then be dispatched to the location to troubleshoot and correct the problem. This array of alarms includes:

- Station DC battery monitoring – remote alarming if protection is disabled;
- Transformer temperatures/gas levels/oil levels – warnings of imminent failures/outages or oil leakage;
- Breaker low gas and trip circuit failure alarms – remote alarming if protection is disabled;
- Intrusion and fire detection alarms – these warn of abnormal conditions or unauthorized access to substation control rooms.

As an example, if the location of a problem is known to a high degree of certainty, the crew can be dispatched with equal certainty, reducing overall restoration time. If required, emergency response procedures can also be activated more quickly, reducing public and environmental risks.

4.6. Operating Authority

FortisBC is centralizing the duties of the distribution person-in-control (“PIC”) and this function will be performed by a dedicated dispatcher at the System Control Center. In the past, the field crews performed the distribution PIC duties and had to physically travel to each substation to operate devices and take station readings. To effectively perform this function from the central System Control Center dispatchers require real-time information about substation equipment such as breaker status, feeder and transformer loadings and bus voltages. This allows them to make appropriate operating decisions and deal with situations as they arise without undue delay.

In addition to the operating efficiencies, WorkSafeBC, the governing authority for worker health and safety regulates the operation of the high voltage power system. Occupational Health and Safety Regulation Part 19.19 states:

“19.19 Person in charge

(1) One person must be assigned at any one time the exclusive authority as the person in charge to establish the conditions for, and to issue safety protection guarantees for, the power system or a part of it.

(2) The person in charge must

*(a) ensure that the **status of the power system or assigned part of the power system is accurately represented on a mimic display** [emphasis added].”*

1 The crucial factor is being able to ensure that the PIC has real-time status of the
2 power system under his/her control, all the while ensuring that they retain control
3 of the system. While it is possible to comply with the Regulation in the absence
4 of automated data collection and remote system operation, the required protocols
5 are more labour intensive, require manual systems of communication and status
6 recording and are to a greater degree open to human error. When the
7 assumption of PIC duties by the System Control Center was initially reviewed,
8 there were two notable benefits identified. The degree of employee safety was
9 considered to be higher since control and status of the system was under the
10 control of a single entity. Secondly, since the field crews were engaged in power
11 restoration and operation and less so in performing PIC duties while in the field,
12 annual operation costs could be reduced by as much as \$100,000 depending on
13 the number of outages and the number of crews working on the power system.

14 **4.7. Remote Operation**

15 There are distinct and discrete benefits associated to having a greater degree of
16 SCADA visibility and control at the System Control Center.

17 a. **Reliability.** Over the last four years FortisBC has averaged 60 feeder
18 outages per year. The average number of customers per feeder (based on
19 those feeders which had outages) is about 850. Many of these outages are in
20 areas remote from the substation, and where a member of the restoration
21 crew must travel to the substation to manually switch to re-energize the
22 feeder. Approximately 30% of these outages were on feeders that originate
23 in substations that already have remote switching capability.

24 If the outage time is reduced by 30 minutes² for the 42 outages per year
25 where there is no remote capability, the result is a reduction of 18,000
26 customer-hours per year. However, on occasion there are methods already
27 employed to reduce outage duration. An employee may be left at the station,
28 ready to switch when the line integrity has been restored, albeit at the

² A typical travel time from an outage location back to the substation (to perform switching to reenergize a feeder) is 30 minutes on average.

1 additional cost of that employee's wages. Additionally, some faults occur at
2 locations less than 30 minutes travel time from the station. Therefore, a
3 conservative estimate of reliability improvement is that 30 minutes can be
4 eliminated from one half of those 42 outages, creating a benefit of 9,000
5 customer-hours per year.

6
7 It should also be noted that as the number of customers connected to the
8 system increases with growth, the reliability improvement increases
9 accordingly.

10 b. **Energy metering.** Wider and more exact visibility and monitoring of system
11 load flow will allow more exact energy and VAR (volt-ampere reactive)
12 management, improving system performance and reducing energy costs.

13 c. **Recloser enabling and disabling.** When crews are brushing a rural line or
14 working on a line that is energized, automatic reclosers must be disabled for
15 safety reasons, requiring one visit to the substation by a PLT in the morning
16 to disable reclosing, and one in the evening to re-enable it. Remote control
17 avoids these labour costs. In 2005, there were approximately 2,350
18 Guarantee of Non-Reclose permits ("GNRs") issued to ensure that work could
19 be done safely. Approximately 15% of GNRs do not require a separate trip to
20 the substation (such as when there are multiple crews working on the same
21 feeder) and about 10% are issued from stations that already have feeder
22 recloser automation. The switching costs are described herein:

23 i) Direct switching costs:

24 Hourly PLT rate (including loadings) = \$75/hour

25 Average travel and tagging time per GNR = 1 hour

26 Number of GNRs that require dedicated time = $2350 \times (1 - 0.1) \times (1 - 0.15) = 1,800$

27 GNR direct cost - \$135,000/year

- 1 ii) Crew must often wait to start work until the switching at the substation is
2 completed and the GNR is issued, confirming that if there is a line fault
3 the circuit will not be re-energized. The estimated crew downtime costs
4 are:
5 a. Brushing crews: 1,000 hours per year @ \$150/hour = \$150,000/year
6 b. Line crews: 1,500 hours per year @ \$75/hour = \$112,500/year
7 Total estimated crew downtime costs = \$ 262,500/year
- 8 d. **Line source switching.** Where distribution substations (for example,
9 Playmor, Tarrys, and Christina Lake) can be fed from two transmission lines
10 remote control of line switches enables faster restoration switching, and
11 avoids labour costs to dispatch a PLT.
- 12 e. **Tap changer operation.** Extending remote control to more distribution tap
13 changers will help to avoid exceeding the peak energy capacity penalty
14 threshold by applying controlled voltage reduction.
- 15 f. **Support for future feeder distribution automation.** As an example, the
16 Program supports the future installation of midpoint line reclosers which can
17 localize the outage effects of a distribution fault, reducing the overall number
18 of customers affected.
- 19 g. **Breaker switching.** Once the problem causing a line fault has been
20 discovered and rectified, the PLT in the field can then contact the System
21 Control Center and confirm the line is safe to re-energize. This can then be
22 done remotely by the System Control Center rather than have the PLT in the
23 field return to the substation and close the distribution breaker. Currently, the
24 outage continues while the PLT travels to the substation to switch the
25 breaker. With automation in place, this additional outage time can be
26 eliminated.
- 27 h. **Feeder switching.** Reconfiguring the local distribution system can be
28 accomplished more rapidly with the ability to switch the feeders remotely.
29 Examples of benefits include:

- 1 • feeding a distribution circuit from another transformer to alleviate loading
2 concerns on the original transformer;
3 • restoring non-faulted feeders faster under station fault conditions once the
4 failure has been identified and isolated.

5 **4.8. Metering**

6 Power system operation will be greatly enhanced with the ability to acquire
7 specific time based load data. In particular:

- 8 a. **Individual feeder metering.** More accurate load profiling, including the
9 information related to time of day and temperature variability will assist in
10 system load balancing. This in turn will reduce the potential for outage and
11 minimize the strain placed on power system equipment.
- 12 b. **Electronic metering.** As opposed to the electromechanical meters that are
13 presently in place, electronic meters improve time resolution of load data and
14 provide improved monitoring of power quality factors. More accurate load
15 profiling improves forecasting and power system planning, ensuring the
16 appropriate and timely deployment of capital expenditures. Improved quality
17 data enables focused troubleshooting and thereby improves customer service
18 as it relates to power quality.

19 More timely data analysis results in faster corrective actions.

20 **4.9. “Intelligent” Relaying**

21 Continuous improvement in electronic technology over the past number of years,
22 including the advent of microprocessors in substation relays, has lead to a much
23 greater ability of the equipment to identify, track and respond to specific problems
24 on the power system. This electronic “intelligence” allows troubleshooting and
25 restoration to be targeted at the problem, with much less time spent by
26 technicians trying to identify what and where the problem is. Specific data that
27 will be acquired and logged includes:

- 1 **a. Fault Location.** With the existing technology, line crews patrol a faulted
2 circuit to determine the nature and location of the fault. The time spent on this
3 patrol activity is completely dedicated to finding the fault, and can be reduced
4 with the use of relays that locate the fault with a higher degree of accuracy.
5 Crew time is better utilized as they spend the bulk of the effort correcting the
6 problem, not searching extensively for it. Restoration time also improves as the
7 relay does the work of better identifying the fault location, enabling crews to be
8 dispatched to a more specific location. While feeder fault location is not entirely
9 accurate (due to the non-homogeneous nature of feeder circuits), the fault
10 location is still useful in providing the relative location of faults.
- 11 **b. Fault Recording.** Collecting and accessing a significantly more detailed
12 event record allows the causes and locations of faults to be analyzed and
13 appropriate remedial action taken. This may include enhanced brushing in
14 certain corridors, equipment replacement/repair, or line relocation as examples.
15 As it pertains to outages and power restoration, there is an added benefit to
16 using more advanced technology. If the outage results from an equipment
17 malfunction within the confines of the substation, the nature of the problem is
18 more likely to be identified by the monitoring devices, which are able to report
19 when they have failed as well as identify the failures of other system
20 components. This saves valuable time and prevents a field patrol of the line,
21 which is standard procedure when equipment trips off and is “locked out”.
- 22 **c. Condition Monitoring.** The highest degree of power system complexity is
23 located within the substation fence. Having detailed ongoing knowledge about
24 the state of equipment allows condition-based, “just in time” maintenance to
25 occur. Currently, most maintenance is time based. However, equipment
26 maintenance is more suitably driven by equipment condition, which can only be
27 done with the availability of condition related data. Information such as the
28 number of circuit breaker operations, transformer oil temperature, dissolved gas
29 values and feeder loading will allow the maintenance cycles to be aligned with

1 the duty that the equipment has performed. Light duty over a period of time will
2 extend the maintenance intervals, thereby reducing the maintenance costs.

3 For example: the scheduled maintenance for a 63 kV SF₆ breaker takes an
4 average of 220 man-hours to maintain, with a maintenance cycle of about six
5 years. This equates to a maintenance cost of approximately \$50,000 per
6 breaker. If the maintenance on one third of these units could be deferred for two
7 years based on a known lower operation duty, the net result is an average cost
8 reduction of approximately 25%. With approximately 60 such breakers in the
9 system, in any given year it is expected that 10 would be maintained. One third
10 of these units represent a cost of \$170,000 annually, which would be reduced to
11 \$125,000, for an annual cost savings of \$45,000.

12 **d. Transformer Replacement.** Currently, when the forecast annual peak load
13 on a large power transformer reaches the nameplate capacity, planning
14 commences for replacement of the unit. Typically, it takes approximately two to
15 three years for planning, engineering, tendering and construction. During this
16 period, as a function of customer growth, the peak load may exceed the
17 nameplate capacity. This is an acceptable risk given that transformer life is
18 normally limited by winding insulation degradation, and relatively short periods of
19 excessive load do not cause significant damage. Insulation is degraded primarily
20 as a result of ongoing heating.

21 It may be possible to keep a transformer in service for even longer periods of
22 time with the availability of consistent, reliable station data. While energized and
23 serving load, the transformer winding does not heat equally, and “hot spots” are
24 created. It is these locations inside the winding, hotter than the average winding
25 temperature that causes the greatest damage and thereby limits the life of the
26 transformer. However, during periods of lower load the temperature rise is not as
27 great and the life of the transformer is reduced at a lower rate.

28 The availability of this information, coupled with information about historical faults
29 on the unit makes it possible for planning engineers to review the “life reduction”
30 of the transformer and better determine how much longer it can safely remain in

1 service. The benefit is seen in the deferral of capital replacements, which in turn
2 limits future rate increases. As an example, a substation transformer
3 replacement typically costs approximately \$2,000,000. A one year deferral would
4 result in a financial benefit of approximately \$75,000.

5 **4.10. Reduced Maintenance Costs**

6 A significant benefit that will be gained from the Program is that all remaining
7 electromechanical meters and relays on distribution feeders will be upgraded to
8 modern standards. This will reduce future maintenance costs as routine relay
9 testing will no longer be required. As well, replacement parts are becoming
10 increasingly difficult to locate for some types of older relays. Some instances of
11 forced upgrades have already occurred when devices have failed and it was
12 either impossible to locate spare parts or it was not cost effective. A recent
13 example occurred in 2006 when a lightning strike near the OK Mission
14 Substation damaged five distribution feeder reclosing relays. Repairing the
15 devices was not practical as replacement components were not available.
16 Instead, it was necessary to replace the units with new microprocessor-based
17 protection relays.

18
19 Microprocessor-based relays have self-diagnostic circuitry that can provide an
20 alarm indication if a device malfunctions. Since the Program will also ensure that
21 the SCC has visibility of all substations, immediate alarming of relay failures will
22 be provided for all locations. This will allow for much quicker response to
23 equipment failures rather than having to wait until a scheduled maintenance
24 interval to determine that a device has failed.

25 **4.11. System Integrity and Security**

26 Station automation reduces the need for redundant sensors, wiring and
27 transducers, which ultimately reduces the capital investment. Unauthorized
28 access and operation is also prevented, enhancing power system “cyber-
29 security”. The FortisBC standard is to ensure forced separation of the

1 operational power system controls such as relaying and SCADA, and those
2 functions that are “read only”, including data logging and equipment monitoring.
3 The Program enables that standards be met and the inherent system security be
4 employed.

5 **4.12. Central database**

6 A significant advantage of microprocessor based systems over their
7 electromechanical predecessors is the ability to collect and log large amounts of
8 data. Once established, the database is continually repopulated creating a
9 history of conditions and equipment performance. Such a growing volume of
10 data becomes a more reliable predictor of future performance, allowing planning
11 engineers to evaluate system needs based on actual performance. Both
12 maintenance and capital upgrade programs can be tailored to the specific needs
13 of the power system rather than relying on manufacturers suggestions and peak
14 load data. The customers become the direct beneficiary on two fronts – greater
15 levels of reliability and lower future costs.

16 In order to gain the full benefits of the Program, new server hardware and
17 software will be installed in the FortisBC Data Centre. This server will be
18 responsible for collecting, aggregating and archiving the data that is received
19 from numerous data sources. These sources include the SCADA system, the
20 power-quality metering system and the Computerized Maintenance Management
21 System.

22 The server will provide a user-friendly web-based interface that will allow users to
23 easily retrieve both historical and real-time data.

24 **5. PUBLIC CONSULTATION**

25 As this Program does not require large new infrastructure to be constructed (the
26 majority of the work will be carried out within the substation control buildings), no
27 public consultation is planned.

1 **6. OTHER APPLICATIONS AND APPROVALS**

2 Approvals from agencies other than the BC Utilities Commission are not
3 required.

4

Appendix 1 – Revenue Requirements Analysis 2006-2026

FortisBC Inc. Capital Project Analysis Distribution Substation Automation Program

Option:1

Line No.	Year: Reference	1 Dec-07	2 Dec-08	3 Dec-09	4 Dec-10	5 Dec-11	6 Dec-12	7 Dec-13	8 Dec-14	9 Dec-15	10 Dec-16	11 Dec-17	12 Dec-18		
Summary															
Revenue Requirements															
1	Operating Expense (Incremental)	Line 59	0	10	25	45	-53	-54	-55	-56	-57	-58	-59	-61	
2	Depreciation Expense	Line 64	0	0	53	198	339	491	591	542	493	443	392	-142	
3	Carrying Costs	Line 71	0	20	93	192	283	346	325	245	168	95	24	-26	
4	Income Tax	Line 85	0	-33	-120	-173	-191	-157	-18	112	193	240	263	61	
5	Total Revenue Requirement for Project		0	-3	51	262	378	627	843	844	797	719	619	-167	
6	Net Present Value of Revenue Requirement		10.00%	1,301											
Rate Impact															
7	Forecast Revenue Requirements		209,300	226,200	244,100	249,000	254,000	259,100	264,300	269,600	275,000	280,500	286,100	291,800	
8	Rate Impact		0.00%	0.00%	0.02%	0.11%	0.15%	0.24%	0.32%	0.31%	0.29%	0.26%	0.22%	-0.06%	
	Annual Incremental Rate Impact over previous year		0.00%	0.00%	0.02%	0.08%	0.04%	0.09%	0.08%	-0.01%	-0.02%	-0.03%	-0.04%	-0.27%	
9	NPV of Project / Total Revenue Requirements		0.05%												
Regulatory Assumptions															
10	Equity Component		40.00%	40.00%	40.00%	40.00%	40.00%	40.00%	40.00%	40.00%	40.00%	40.00%	40.00%	40.00%	
11	Debt Component		60.00%	60.00%	60.00%	60.00%	60.00%	60.00%	60.00%	60.00%	60.00%	60.00%	60.00%	60.00%	
12	Equity Return		8.77%	9.19%	9.19%	9.19%	9.19%	9.19%	9.19%	9.19%	9.19%	9.19%	9.19%	9.19%	
13	Debt Return		6.40%	6.50%	6.50%	6.50%	6.50%	6.50%	6.50%	6.50%	6.50%	6.50%	6.50%	6.50%	
Capital Cost															
14	Bell Terminal		24										0	0	
15	Castlegar		345												
16	Duck Lake		131												
17	Fruitvale		42												
18	Glenmore		125												
19	Hollywood		375												
20	Kermelos		54												
21	Summerland		89												
22	Beaver Park		152												
23	Blueberry		140												
24	OK Mission		383												
25	Osoyoos		122												
26	Playmor		183												
27	Saucier		37												
28	Valhalla		91												
29	Westminster		140												
30	Christina Lake		180												
31	Glenmerry		186												
32	Hedley		348												
33	Salmo		155												
34	Trout Creek		223												
35	West Bench		286												
36	Huth		190												
37	Passmore		139												
38	Sexsmith		272												
39	Slocan City		95												
40	Stoney Creek		291												
41	Tarrys		348												
42	Data Server hardware & software		140	33	0	0									
43	Initial engineering, estimating, procurement		462												
44	Capital Cost Subtotal		462	1,324	1,281	1,378	1,336								
45	Contingency (10%)		46	132	128	138	134								
46	AFUDC		18	0	0	0	0								
47	Cumulative Project Cost Subtotal		526	1,983	3,392	4,908	6,378								
48	Estimated Annual Capital Savings				-472	-481	-491	-501	-511	-521	-532	-542			
49	Total Cash Outlay in Year		526	1,456	1,409	1,516	998	-481	-491	-501	-511	-521	-532	-542	
50	Cumulative Cash Outlay		526	1,983	3,392	4,908	5,906	5,424	4,933	4,432	3,921	3,400	2,869	2,327	
51	Cumulative Project Cost		0	0	0	0	0	0	0	0	0	0	0	0	
52		526	1,456	1,936	3,499	4,390	4,427	5,415	4,923	4,422	3,911	3,390	2,858		
Annual Operating Costs / (Savings)															
56	Estimated Cost Savings							-118	-120	-123	-125	-128	-130	-133	-136
57	Communications - Leased Line Costs		10	20	40	60	61	62	64	65	66	68	69		
58	Software Maintenance Costs				5	5	5	5	6	6	6	6	6	6	
59	Total Incremental Operating Costs (Savings) (Forecast inflation rate 2%)		0	10	25	45	-53	-54	-55	-56	-57	-58	-59	-61	
Depreciation Expense															
60	Opening Cash Outlay		0	0	526	1,983	3,392	4,908	5,906	5,424	4,933	4,432	3,921	3,400	
61	Additions in Year	Line 53	0	526	1,456	1,409	1,516	998	-481	-491	-501	-511	-521	-532	
62	Cumulative Total		0	526	1,983	3,392	4,908	5,906	5,424	4,933	4,432	3,921	3,400	2,869	
63	Depreciation Rate - composite average		10.00%	10.00%	10.00%	10.00%	10.00%	10.00%	10.00%	10.00%	10.00%	10.00%	10.00%	10.00%	
64	Depreciation Expense		0	0	53	198	339	491	591	542	493	443	392	-142	
Net Book Value															

FortisBC Inc.

Distribution Substation Automation Program

**FortisBC Inc.
Capital Project Analysis
Distribution Substation Automation Program**

Option:1

Line No.	Year: Reference	13 Dec-19	14 Dec-20	15 Dec-21	16 Dec-22	17 Dec-23	18 Dec-24	19 Dec-25	20 Dec-26
Summary									
Revenue Requirements									
1	Operating Expense (Incremental)	Line 59	-62	-63	-64	-66	-67	-68	-70
2	Depreciation Expense	Line 64	-532	-542	-553	-564	-575	-587	-599
3	Carrying Costs	Line 71	-41	-41	-42	-43	-44	-45	-46
4	Income Tax	Line 85	-81	-62	-49	-40	-33	-29	-26
5	Total Revenue Requirement for Project		-715	-709	-708	-713	-720	-729	-740
6	Net Present Value of Revenue Requirement		10.00%						
Rate Impact									
7	Forecast Revenue Requirements		297,600	303,600	309,700	315,900	322,200	328,600	335,200
8	Rate Impact		-0.24%	-0.23%	-0.23%	-0.23%	-0.22%	-0.22%	-0.22%
	Annual Incremental Rate Impact over previous year		-0.18%	0.01%	0.00%	0.00%	0.00%	0.00%	0.00%
9	NPV of Project / Total Revenue Requirements								
Regulatory Assumptions									
10	Equity Component		40.00%	40.00%	40.00%	40.00%	40.00%	40.00%	40.00%
11	Debt Component		60.00%	60.00%	60.00%	60.00%	60.00%	60.00%	60.00%
12	Equity Return		9.19%	9.19%	9.19%	9.19%	9.19%	9.19%	9.19%
13	Debt Return		6.50%	6.50%	6.50%	6.50%	6.50%	6.50%	6.50%
Capital Cost									
14	Bell Terminal		0	0	0	0	0	0	0
15	Castlegar								
16	Duck Lake								
17	Fruitvale								
18	Glenmore								
19	Hollywood								
20	Keremeos								
21	Summerland								
22	Beaver Park								
23	Blueberry								
24	OK Mission								
25	Osoyoos								
26	Playmor								
27	Saucier								
28	Valhalla								
29	Westminster								
30	Christina Lake								
31	Glenmerry								
32	Hedley								
33	Salmo								
34	Trout Creek								
35	West Bench								
36	Huth								
37	Passmore								
38	Sexsmith								
39	Slocan City								
40	Stoney Creek								
41	Tarrys								
42	Data Server hardware & software								
43	Initial engineering, estimating, procurement								
44	Capital Cost Subtotal								
45	Contingency (10%)								
46	AFUDC								
47	Cumulative Project Cost Subtotal								
48	Estimated Annual Capital Savings		-553	-564	-575	-587	-599	-611	-623
49	Total Cash Outlay in Year		-553	-564	-575	-587	-599	-611	-623
50	Cumulative Cash Outlay		1,774	1,209	634	47	-551	-1,162	-1,785
51			0	0	0	0	0	0	-2,420
52	Cumulative Project Cost		1,774	1,209	634	47	-551	-1,162	-1,785
53	Additions to Plant		-542	-553	-564	-575	-587	-599	-611
54	Cumulative Additions to Plant		2,327	1,774	1,209	634	47	-551	-1,162
55	CWIP		2,316	1,763	1,198	623	36	-563	-1,174
Annual Operating Costs / (Savings)									
56	Estimated Cost Savings		-138	-141	-144	-147	-150	-153	-156
57	Communications - Leased Line Costs		70	72	73	75	76	78	79
58	Software Maintenance Costs		6	6	6	6	7	7	8
59	Total Incremental Operating Costs (Savings) (Forecast inflation rate 2%)		-62	-63	-64	-66	-67	-68	-70
Depreciation Expense									
60	Opening Cash Outlay		2,869	2,327	1,774	1,209	634	47	-551
61	Additions in Year	Line 53	-542	-553	-564	-575	-587	-599	-611
62	Cumulative Total		2,327	1,774	1,209	634	47	-551	-1,162
63	Depreciation Rate - composite average		10.00%	10.00%	10.00%	10.00%	10.00%	10.00%	10.00%
64	Depreciation Expense		-532	-542	-553	-564	-575	-587	-599
Net Book Value									
65	Gross Property	Line 54	2,327	1,774	1,209	634	47	-551	-1,162
66	Accumulated Depreciation		-2,869	-2,327	-1,774	-1,209	-634	-47	551
67	Net Book Value		-542	-553	-564	-575	-587	-599	-611
Carrying Costs on Average NBV									
68	Return on Equity		-20	-20	-21	-21	-21	-22	-22
69	Interest Expense		-21	-21	-22	-22	-23	-23	-24
70	AFUDC		0	0	0	0	0	0	0
71	Total Carrying Costs		-41	-41	-42	-43	-44	-45	-46
Income Tax Expense									
72	Combined Income Tax Rate		30.50%	30.50%	30.50%	30.50%	30.50%	30.50%	30.50%
Income Tax on Equity Return									
73	Return on Equity	Line 68	-20	-20	-21	-21	-21	-22	-22
74	Gross up for revenue (Return / (1- tax rate))		-28	-29	-30	-30	-31	-32	-33
75	Less: Income tax on Equity Return		-9	-9	-9	-9	-9	-10	-10
76	Net Income (equal return on equity)		-20	-20	-21	-21	-21	-22	-22
Income Tax on Timing Differences									
77	Depreciation Expense		-532	-542	-553	-564	-575	-587	-599
78	Less: Capital Cost Allowance	Line 92	-367	-421	-462	-495	-521	-542	-561
79	Total Timing Differences		-165	-121	-91	-69	-55	-45	-38
80	Income Tax on Timing Differences		-50	-37	-28	-21	-17	-14	-11
81	Before Tax Revenue Requirement [=Line 52/(1-tax)]		-72	-53	-40	-30	-24	-20	-17
85	Total Income Tax	Lines 75 + 81	-81	-62	-49	-40	-33	-29	-26
Capital Cost Allowance									
86	Opening Balance - UCC		-952	-1,127	-1,259	-1,361	-1,442	-1,508	-1,564
87	Additions to Plant		-542	-553	-564	-575	-587	-599	-611
88	Subtotal UCC		-1,494	-1,680	-1,823	-1,936	-2,029	-2,107	-2,175
89	Capital Cost Allowance Rate		30.00%	30.00%	30.00%	30.00%	30.00%	30.00%	30.00%
90	CCA on Opening Balance		-286	-338	-378	-408	-433	-452	-469
91	CCA on Capital Expenditures (1/2 yr rule)		-81	-83	-85	-86	-88	-90	-92
92	Total CCA		-367	-421	-462	-495	-521	-542	-561
93	Ending Balance UCC		-1,127	-1,259	-1,361	-1,442	-1,508	-1,564	-1,614