



David Bennett
Vice President, Regulatory Affairs
and General Counsel

FortisBC Inc.
Regulatory Affairs Department
1290 Esplanade Box 130
Trail BC V1R 4L4
Ph: 250 717 0853
regulatory@fortisbc.com
www.fortisbc.com

November 2, 2007

Via Email
Original via mail

Ms. Erica M. Hamilton
Commission Secretary
BC Utilities Commission
Sixth Floor, 900 Howe Street, Box 250
Vancouver, BC V6Z 2N3

Dear Ms. Hamilton:

Re: An Application for a CPCN for the Distribution Substation Automation Program

Please find enclosed FortisBC Inc.'s response to Information Request No. 1 from BCOAPO et al and Mr. Alan Wait.

Sincerely,

A handwritten signature in black ink, appearing to read "D. Bennett". The signature is stylized and cursive.

David Bennett
Vice President, Regulatory Affairs
and General Counsel

cc: Registered Intervenors

PROJECT NAME: Distribution Substation Automation CPCN Application 3698477

REQUESTOR NAME: BCOAPO et al

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

1 **1** **Reference: August 28, 2007 Application (“The Application”), page 3, lines**
2 **4-8**
3 **and pages 26-29**

4 **Q1.1 Are technical losses all a function of system design?**

5 A1.1 Technical losses are a function of system load, design (system impedance) and
6 operating configuration.

7
8 **Q1.2 Is the ability that the Program will provide to monitor individual distribution**
9 **feeder loads (and subsequently move loads between feeders to optimize**
10 **system performance) expected to reduce overall system losses? If so, is**
11 **there an estimate of the potential savings?**

12 A1.2 Monitoring individual distribution loads provides the data to evaluate optimal
13 switching which would result in reduced overall system losses. However, without
14 the current coincidental individual feeder load information to refine the models
15 there is no means to estimate the potential savings.

16
17 **2** **Reference: The Application, page 7, lines 8-13 and page 37, lines 16-21**

18 **Q2.1 Please indicate what other utilities have installed similar automation**
19 **systems; communication systems or informational databases.**

20 A2.1 The protection, metering, communications and RTU hardware proposed by the
21 Program is used by the majority of electric utilities in North America. As a local
22 example, BC Hydro/BCTC installs essentially the same protection, metering and
23 RTU hardware as FortisBC. BCTC also has a data historian server.

PROJECT NAME: Distribution Substation Automation CPCN Application 3698477

REQUESTOR NAME: BCOAPO et al

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

1 **Q2.2 Has FortisBC directly contacted any of these utilities regarding their**
2 **experience with these systems and databases? If so, please summarize**
3 **the feedback received.**

4 A2.2 FortisBC staff has discussed the application of these systems with counterparts
5 at numerous other utilities. The nature of the conversations has been informal
6 and extend over a lengthy period. These conversations have reiterated the
7 many benefits listed in Section 4 of the Application that automation systems
8 provide.

9
10 Please also see the response to BCUC IR1, Appendix A15.1, which contains a
11 survey of North American utility investment in transmission and distribution
12 automation.

13
14 **Q2.3 Please indicate where on FortisBC's system such technology has been**
15 **installed and for how long it has been in place.**

16 A2.3 FortisBC has been using technology systems as described below:

System	First installed
Intelligent relaying (SEL relays)	1995
Power-quality monitoring devices (PML meters)	1994
SCADA RTU's (GE RTU's)	1999
Power-quality monitoring database (PML)	1996

17
18 These systems have been applied as standard packages with all recent
19 distribution substation projects. Examples include: Cascade Substation
20 (completed in 1999), Lambert Substation (completed in 2004), Waterford
21 Substation (completed in 2006) and the Cottonwood Substation (completed in
22 2007).

PROJECT NAME: Distribution Substation Automation CPCN Application 3698477

REQUESTOR NAME: BCOAPO et al

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

1 **Q2.4 Given that FortisBC already has similar equipment in place that has been**
2 **successful in enabling the desired outcome, please explain why the current**
3 **archiving server hardware and software are inadequate and new hardware**
4 **and software are required.**

5 A2.4 The current archiving server hardware and software only interfaces to power-
6 quality meters. It is a very comprehensive system which is capable of collecting
7 large amounts of detailed metering data such as voltage, amperage, load and
8 energy readings; sag/swell disturbance information; waveform recordings; and
9 individual harmonic readings. This results in huge amounts of data which is
10 prohibitive to archive for long periods. In general, the existing system is not well
11 suited to very long term storage and retrieval of data. As well, since the metering
12 system is not capable of connecting to the FortisBC SCADA system (due to
13 protocol incompatibilities), there is a large amount of data which is not currently
14 accessible to general users.

15
16 The data historian hardware and software proposed as part of the Program would
17 link to the metering and SCADA systems (as well as the Computerized
18 Maintenance Management System in the future) and is complementary to them.

19
20 The data historian offers three significant benefits:

- 21 1. It supports multiple data acquisition protocols and is thus able to link to
22 diverse systems such as the metering, SCADA and maintenance
23 management systems.
- 24 2. It allows selective, long-term archiving of key information (primarily load
25 readings) from either the metering or SCADA systems.
- 26 3. It provides a unified interface and repository for the data. Any FortisBC user
27 would be able to query the archive and generate reports as needed.

28

PROJECT NAME: Distribution Substation Automation CPCN Application 3698477
REQUESTOR NAME: BCOAPO et al
PROJECT INFORMATION REQUEST NO: 1
TO: FortisBC Inc.
REQUEST DATE: October 24, 2007
RESPONSE DATE: November 2, 2007

1 Following is an excerpt from the specification of the historian software:

2
3 *“The purpose of this subsystem is to store real-time and historical process*
4 *values along with their respective qualities in a long term, online disk*
5 *storage file system, while providing the means for users to access this*
6 *data, display high-quality graphics, plot and trend this data, and*
7 *import/export this data for offline analysis. The historian system must be*
8 *designed to accommodate very large real-time and historical databases*
9 *such that every process point is stored online for years in its original*
10 *collected resolution. The historian compression must not, in any way,*
11 *affect nor filter the data from its original resolution and sampled state. The*
12 *historian system must provide for the ability to implement sophisticated*
13 *performance-based calculations external to the SCADA system, and the*
14 *results of these calculations must be stored in the historian database.”*
15 *Reference: Instep Software, LLC – “Typical Requirements for a*
16 *Comprehensive Data Historian”*

17
18 **3 Reference: The Application, pages 12-13; page 23; and pages 39-40**
19 **FortisBC Response to BCUC Staff IR #3.4**

20
21 **Q3.1 Please indicate the anticipated in-service dates for the new distribution**
22 **stations that are not included in the scope of the current Application (page**
23 **12, lines 2-15).**

24 A3.1 Following are the in-service dates for the listed substations:

- 25 a. Cottonwood (south of Nelson) – Q3 of 2007 (actual)
26 b. Arawana (Naramata) – Q4 of 2009 (estimated)
27 c. Kettle Valley (east of Rock Creek) – Q2 of 2008 (estimated)
28 d. Nk'Mip (east Osoyoos) – Q4 of 2007 (actual)

PROJECT NAME: Distribution Substation Automation CPCN Application 3698477

REQUESTOR NAME: BCOAPO et al

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

- 1 e. Big White (Big White Village) – Q4 of 2008 (estimated)
- 2 f. Ellison (north Kelowna) – Q4 of 2008 (estimated)
- 3 g. Black Mountain (east Kelowna) – Q1 of 2009 (estimated)
- 4 h. Ootischenia (east of Castlegar) – Q4 of 2008 (estimated)

5

6 **Q3.2 Please indicate the anticipated retirement dates for the older substations**
7 **that are not included in the program (page 12, lines 17-30).**

8 A3.2 Listed below are the dates which the substations would no longer be used to
9 supply the distribution system.

- 10 a. Naramata – Q4 of 2009 (estimated)
- 11 b. Wynndel – Q3 of 2007 (actual)
- 12 c. Rock Creek– Q3 of 2008 (estimated)
- 13 d. Midway – Q3 of 2008 (estimated)
- 14 e. Greenwood – Q4 of 2009 (estimated)
- 15 f. Paterson – Q4 of 2007 (estimated)
- 16 g. Whitewater– Q4 of 2007 (actual)
- 17 h. Ymir – Q3 of 2011 (estimated)

18

19 **Q3.3 With respect to the response to BCUC Staff IR #3.4, does this mean that the**
20 **full benefits of the program will not be achieved until the all the new**
21 **substations are also in-service and the older substations have all been**
22 **decommissioned/replaced? If not, why not?**

23 A3.3 To gain maximum benefits from the Program it is necessary to have the systems
24 described installed in all distribution substation locations. Since it is not possible
25 to predict where outages or failures will occur, remote visibility should be
26 extended to all substations to ensure that the FortisBC System Control Centre is
27 aware of problems, no matter where they occur. The older stations listed in A3.2
28 will be retired before the end of the program.

PROJECT NAME: Distribution Substation Automation CPCN Application 3698477

REQUESTOR NAME: BCOAPO et al

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

1

2 **Q3.4 If the response to part 3.3 is yes, are the benefits set out in Table 5 (page**
3 **23) those attributable to full scale implementation at all substations or the**
4 **(partial) benefits from the actual program?**

5 A3.4 The benefits listed in Table 5 are attributable to full scale implementation of the
6 Program. However, it should be noted that even with a staged deployment of the
7 proposed systems, that some of the benefits can be achieved immediately. It is
8 on this basis that FortisBC has been installing the systems at all recently
9 constructed substations.

10

11 **Q3.5 Please confirm that the Revenue Requirement Analysis presented in**
12 **Appendix 1 assumes the full program benefits are available starting in 2011**
13 **with the completion of the program. If the dates provided in response to**
14 **3.1 or 3.1 extend beyond 2011:**

- 15
 - **Please comment on the reasonableness of this assumption, and**
 - **Please redo the Revenue Requirement Analysis, with the benefits**
- 17 **starting upon full equipment installation at all substations.**

18 A3.5 Confirmed. Since the new stations will be completed and the older stations
19 removed from service by the end of 2011, the original assumptions made in the
20 NPV analysis are still valid and no revision is necessary.

PROJECT NAME: Distribution Substation Automation CPCN Application 3698477

REQUESTOR NAME: BCOAPO et al

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

1 **4 Reference: The Application, page 12**

2 **FortisBC Response to BCUC Staff IR#3.4**

3 **Q4.1 Are there any benefits to be derived from installing the automation systems**
4 **at the new substations (page 12, lines 7-15), if the proposed program does**
5 **not proceed? If so, please indicate (both qualitatively and quantitatively)**
6 **what they are.**

7 A4.1 Even if the automation systems are not deployed at all locations, the stations that
8 are equipped with the systems would gain the benefits listed in Section 4 of the
9 Application. For example, there would be localized improvements in reliability
10 and safety that would result from remote control and visibility. Localized load
11 forecasting would also be improved by having accurate transformer and feeder
12 historical loading information. The benefits would be proportional to the number
13 of stations that had the required systems versus those that did not.

14
15 **Q4.2 If the benefits of the Program are dependent upon full deployment of**
16 **automation systems at all substations, why wasn't the NPV calculated**
17 **based on the cost of installing new equipment at all substations, including**
18 **the new substations listed on page 12? Please indicate why this wouldn't**
19 **be a more appropriate basis on which to do the analysis.**

20 A4.2 The localized benefits gained from the automation systems are significant and
21 thus these systems are considered standard and included in all new substation
22 project designs and estimates. Please also refer to the responses to Q3.4 and
23 Q4.1.

1 **5 Reference: The Application, Appendix I**

2 **Q5.1 Please indicate the basis for the discount rate of 10% used in the NPV**
3 **analysis.**

4 A5.1 The discount rate is based on a real discount rate of 8% plus inflation of 2%.
5 FortisBC has used a real discount rate of 8% as a base case in evaluating its
6 capital expenditures for a number of years.

7
8 **6 Reference: FortisBC Response to BCUC Staff IR #5.1**

9 **Q6.1 Please confirm that under the current PBR plan that applies to FortisBC,**
10 **O&M savings that result in a variance to after-tax return on equity are only**
11 **shared (equally) between the Company and the rate payers to the extent**
12 **the savings lead to an ROE that is 0.5 percentage points higher than the**
13 **approved ROE.**

14 A6.1 Under the current PBR ROE Sharing Mechanism, a 2% collar has been set
15 around the allowed ROE whereby variances (adjusted for certain revenue and
16 cost variances which flow through to customers) as a result of actual financial
17 performance, positive or negative, will be shared equally between customers and
18 the shareholder. There is no 0.5% threshold.

19
20 **Q6.2 Based on FortisBC's current 2007 projected rate base and cost of capital,**
21 **what level of annual O&M savings would produce a 0.5% variance in after-**
22 **tax return on equity?**

23 A6.2 Based on FortisBC's 2007 Approved Revenue Requirements of \$209,480,000,
24 O&M savings of approximately \$1,050,000 would be required to produce a 0.5%
25 variance in after-tax ROE. As stated in the response to Q6.1, all variances in
26 after-tax ROE within a 2.0% range are shared equally between customers and
27 the shareholder.

28

PROJECT NAME: Distribution Substation Automation CPCN Application 3698477

REQUESTOR NAME: BCOAPO et al

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

- 1 **7 Reference: The Application, page 3, lines 10-12Appendix I**
- 2 **Q7.1 The Executive Summary indicates that the automated systems permit**
- 3 **power transformer life to be more precisely measured over time. Please**
- 4 **indicate where, in section 4, this particular benefit is discussed and valued.**
- 5 **A7.1 This benefit is discussed and valued in Section 4.9.d “Transformer**
- 6 **Replacement.”**

PROJECT NAME: Distribution Substation Automation CPCN Application

REQUESTOR NAME: Mr. Alan Wait

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

1 **1. Reference BCUC IR A.2.1**

2 **Q1.1 Why if the server hardware lasts for only 5 years is it depreciated at 10.6%**
3 **rather than 20%?**

4 A1.1 The Company depreciates fixed assets by asset pool. For computer equipment,
5 the FortisBC approved rate is 10.6%.

6
7 **2. Ref. item 4.4**

8 **Q2.1 Confirm that FortisBC expects the line loss reduction of 1 to 2% is from**
9 **9.5% to 8.5% or 7.5%. Does that figure include line losses in the wheeling of**
10 **power by BC Transmission?**

11 A2.1 FortisBC believes there is a potential of further reductions to system losses of 1-
12 2% and this could mean a reduction from 9.5% to 8.5% or 7.5% if system
13 improvements were made and load growth remained static. However, as system
14 improvements reduce losses, system growth tends to increase losses; therefore,
15 the net loss level is dependent on both factors. It is unlikely that system losses
16 could be sustained at less than 8.5%.

17

18 The 9.5% loss level includes losses from wheeling of power by BCTC.

19

20 **3. Ref. Table 5**

21 **Q3.1 Please show how average benefits of table 5, P.23 of \$590,000 becomes the**
22 **figures shown on line 56 of Appendix A.**

23 A3.1 As discussed in Section 3.5 of the Application, the average value of the savings
24 (\$590,000) is allocated as 80% towards future capital reductions and 20% to
25 operating cost reductions. Thus, $\$590,000 \times 20\% = \$118,000$. This is the figure
26 shown on line 56 of Appendix A. This value is then escalated at 2% per year
27 beyond 2011.

PROJECT NAME: Distribution Substation Automation CPCN Application

REQUESTOR NAME: Mr. Alan Wait

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

1 **4. Ref. 4.9.d**

2 **Q4.1 Please show the calculation for a \$2 mil transformer replacement that**
3 **results in a \$75,000/year cost to ratepayers.**

4 A4.1 The requested information is provided below.

1	Transformer Acquisition		\$	2,000,000		
2						
3	Mid Year Rate Base (year 1)		\$	1,000,000		
4						
5		Capital				
6	Cost of Debt	Structure				
7	Cost of Equity	60%	\$	600,000	6.43%	\$ 38,580
8	Tax on Equity	40%	\$	400,000	9.19%	36,760
9	Income Tax on Timing Difference				32.5%	17,699
10	Leased line costs (Estimate)				Line 20	(26,000)
11	Depreciation					8,000
12	Tax timing differences				3.0%	-
13	Year 1 Revenue Requirement impact					\$ 75,039
14						
15	<u>Tax Timing Differences:</u>					
16	CCA 1/2 year rule	8.0%				\$ 80,000
17	Depreciation	3.0%				-
18						\$ 80,000
19						
5	20	Income Tax on Timing Difference			32.5%	\$ 26,000

6

7 **5. Ref. P.18, L.27&28**

8 **Q5.1 Please show the assumptions and calculations used for the savings in**
9 **capital costs which represent some 80% of the expected savings. Which**
10 **transformers would be expected to last longer and how much longer?**

11 A5.1 In the case of the future capital cost savings, most of this savings is due to
12 reduced labour costs during major outages. The rationale for the 80/20%
13 allocation is explained in Section 3.5 of the application and further confirmed in
14 the response to BCUC IR1 Q24.1.

15

16 The savings due to avoided transformer upgrades will be sporadic. However, as
17 the system load continues to grow, more transformers will be reaching their
18 nameplate capacity. The monitoring to be installed by this program will assist in

PROJECT NAME: Distribution Substation Automation CPCN Application

REQUESTOR NAME: Mr. Alan Wait

PROJECT INFORMATION REQUEST NO: 1

TO: FortisBC Inc.

REQUEST DATE: October 24, 2007

RESPONSE DATE: November 2, 2007

- 1 determining if a transformer replacement can be deferred by permitting a limited
- 2 amount of short-duration overloads. Transformers affected will depend on where
- 3 the load growth is more rapid.