

David Bennett Vice President, Regulatory Affairs & General Counsel

FortisBC Inc. Suite 100 - 1975 Springfield Road Kelowna, BC V1Y 7V7 Ph: 250 717 0853 Fax: 866 605 9431 regulatory@fortisbc.com www.fortisbc.com

April 22, 2008

<u>Via Email</u> Original via Courier

Ms. Erica M. Hamilton Commission Secretary BC Utilities Commission Sixth Floor, 900 Howe Street, Box 250 Vancouver, BC V6Z 2N3

Dear Ms. Hamilton:

Re: An Application for a CPCN for the Okanagan Transmission Reinforcement (OTR) Project No. 3698488 -Outstanding Information Requests

Please find enclosed 20 copies of FortisBC Inc.'s responses to BCUC IR2 Q80.2 and Q80.3, Harlingten Q5.1, Karow Q9 and Q12, and SOFAR/Wiltse Q10.7 and Q10.8.

Sincerely,

David Bennett Vice President, Regulatory Affairs and General Counsel

cc: Registered Intervenors

Project No. 3698488: Okanagan Transmission Reinforcement (OTR) Project
Requestor Name: BC Utilities Commission
Information Request No: 2 - Outstanding from April 17/08
To: FortisBC Inc.
Request Date: March 27, 2008
Response Date: April 22, 2008

- 1 BCUC IR2
- Q80.2 Please provide descriptions of corona emissions and noise as Non Financial Factors, consistent with the description of other factors in Section
 4.3.3 of Exhibit B-1-1.
- A80.2 The corona emissions of transmission lines manifest as radio interference and
 audible noise and have weather dependency worst during foggy and rainy
 weather conditions. With good design, installation and maintenance, the
 emissions from the new lines will be higher but should not be significantly more
 noticeable than the existing 76 Line. Audible noise will not be intrusive beyond the
 right-of-way edge in dry weather. In wet weather the noise may be more
 noticeable at the right-of-way edge but not in neighbouring houses.
- All line designs will comply with regulations as noted in response to BCUC IR2Q80.1.
- 14 Description:

Corona Emissions (radio frequency) – considers Project compliance with
 Industry Canada Standards. All alternatives will be within Industry Canada
 Standards. FortisBC has ranked the alternatives based on the number of
 conductors, proximity and frequency of passage expected on or immediately
 adjacent to the right-of-way.

20 2. Corona Emissions (audible noise) – FortisBC has ranked the alternatives
 21 based on the number of conductors, proximity and frequency of passage expected
 22 on or immediately adjacent to the right-of-way.

Project No. 3698488: Okanagan Transmission Reinforcement (OTR) Project
Requestor Name: BC Utilities Commission
Information Request No: 2 - Outstanding from April 17/08
To: FortisBC Inc.
Request Date: March 27, 2008
Response Date: April 22, 2008

Q80.3 Please provide a comparison of the project alternatives with respect to
 corona emissions and noise that is similar to Table 4-3-3D, and include
 Weighting Factors that correspond to those for the other Non-Financial
 Factors and a discussion explaining the reasons for the numbers that
 FortisBC assigned to corona emissions and noise.

- 6 A80.3 A comparison similar to Table 4-3-3D is shown below as BCUC Table A80.3.
- As the impacts are both related to corona emissions, a combined weighting of 5 is
 used, with audible noise ranked slightly higher for impacts. As the effects of
 corona emission are linked, as expected there are no differences between the
 radio frequency and audible noise ratings of a particular alternative.
- As the impacts are related to human activity and proximity, the Alternatives that locate the lines Upland (Alternative 2A and 2B) are ranked higher than ones that use the existing right-of-way. For Alternatives that are within the existing right-ofway, the ones with one transmission line or three conductors (Alternative 1C and 3) rank higher than ones with six conductors (Alternative 1A and 1B) for corona
- 16 emissions.

Project No. 3698488: Okanagan Transmission Reinforcement (OTR) Project Requestor Name: BC Utilities Commission Information Request No: 2 - Outstanding from April 17/08 To: FortisBC Inc. Request Date: March 27, 2008 Response Date: April 22, 2008

1	BCUC Table A80.3: Non Financial Comparison of Route Alternatives –Corona Emissions –
2	Radio Interference and Audible Noise
3	(1 = lowest ranking: 5 = highest ranking)

4

	Criterion	Weighting Factors	Alte Existir Single	rnative 1A ng Corridor – Pole Double Circuit	Alter Existin H-Fra	rnative 1B ng Corridor – me Double Circuit	Alter Existin – H-Fr High (rnative 1C ng Corridor ame Single Capacity Circuit	Alter Uplan Pole C	native 2A Id - Single Double ircuit	Alter Upland Ci	native 2B -Two Single ircuits	Alter Two Circu Exist U	rnative 3 o Single lits – One ting, One pland
			Rank	Weighted Rank	Rank	Weighted Rank	Rank	Weighted Rank	Rank	Weighted Rank	Rank	Weighted Rank	Rank	Weighted Rank
1	Corona Emissions (radio frequency)	2	2	4	2	4	3	6	5	10	5	10	3	6
2	Corona Emissions (audible noise)	3	2	6	2	6	3	9	5	15	5	15	3	9
3	Total	5		10		10		15		25		25		15

Project No. 3698488: Okanagan Transmission Reinforcement (OTR) Project
Requestor Name: Colin Harlingten
Information Request No: 1 - Outstanding from April 17/08
To: FortisBC Inc.
Request Date: March 27, 2008
Response Date: April 22, 2008

1 Harlingten IR1

- 2 **5.** Corona lon Emissions
- 3 Reference:

4 Q5.1 For all of the options 1A through 3 please indicate the level of Corona Ion 5 emissions on average and at a maximum

- 6 A5.1 The calculated corona ion (ozone) emissions are minimal. The worst case
- 7 conditions occur near to the conductors and results are listed below. For
- 8 conditions at the right-of-way edge the results were below detectable levels.
- 9 10

Harlingten Table A5.1

Alternative	Ozone Concentration Maximum (parts per billion)
Existing 76Line (161kV)	0.25
Alternative 1A (2A)	3.0
Alternative 1B	2.7
Alternative 1C	1.8
Alternative 2B	2.4
Alternative 3	2.3

11 Alternatives 1A and 2A are the same line designs; therefore the results are the 12 same. Project No. 3698488: Okanagan Transmission Reinforcement (OTR) Project Requestor Name: Hans Karow Information Request No: 1 - Outstanding from April 17/08 To: FortisBC Inc. Request Date: March 27, 2008 Response Date: April 22, 2008

1 KAROW IR1

Q9 Please provide the actual calculated magnetic field value numbers at
 distances of every 5 meters from the centre of the line as far as down to 0.3
 milliGauss on a table for all four magnetic field profiles shown on for the
 present and upgraded lines.

A9 Please see Karow Attachment A9 for the calculated magnetic field value
numbers at distances of every five meters from the center of the line down to
0.3 milliGauss for four magnetic field profiles shown for the existing 76 Line
and for Alternatives 1A, 1B and 1C. For the double circuit Alternatives 1A and

1B, the calculations are based on opposing phasing configuration to mitigatemagnetic fields.

			Magnetic	Field vs	Distance	•			
		Evicting	76 Lino ot	Alterna	tive 1A -	Alternat	ive 1B -	Alternat	ive 1C -
	Distance	Existing 16	1kV	Pouble Cli	ole	fra	me	Capacity	H-frame
	from								
	Centre of Right of	Average Case	Maximum Case	Average Case	Maximum Case	Average Case	Maximum Case	Average Case	Maximun Case
	Way (m) -300	(mG)	(mG) 0 .						
	-295								0.3
	-290 -285								0.3
	-280 -275								0.3
	-270 -265								0.3
	-260								0.3
	-255 -250								0.4
	-245 -240								0.4
	-235								0.4
	-225								0.5
	-220								0.5
	-210 -205								0.6
	-200 -195		0.31						0.6
	-190 -185		0.32						0.7
	-180		0.36				0.3		0.8
	-175 -170		0.38				0.32		0.8
	-165 -160		0.42				0.36		0.9
	-155		0.48				0.41		1.1
	-145		0.54				0.46		1.2
	-140 -135		0.58				0.5 0.53	0.29	1.3 1.4
	-130 -125		0.66				0.58	0.31 0.34	1.5
	-120		0.77				0.68	0.37	1.8
	-110	0.31	0.04				0.81	0.44	2.1
	-105 -100	0.34	0.99				0.89 0.98	0.48	2. 2.6
	-95 -90	0.41	1.19 1.31				1.09	0.59	2.9
	-85	0.5	1.46			0.27	1.36 1.54	0.73	3.6 4 1
	-75	0.63	1.83		0.27	0.35	1.75	0.93	4.6
	-70 -65	0.71	2.07		0.33	0.4	2.02	1.07	5.3 6.1
	-60 -55	0.93	2.71 3.16		0.51	0.55	2.76 3.3	1.45 1.72	7.2
	-50 -45	1.28	3.72 4 44		0.84	0.8	4 97	2.07	10.3 12 6
	-40	1.85	5.39	0.3	1.51	1.26	6.31	3.17	15.8
	-35 -30	2.29	8.48	0.42	3.07	2.25	8.27	4.07	20.3
Edge of R/W	-25 -20	3.82 5.19	11.1 15.1	0.93	4.62 7.28	3.19 4.71	15.93 23.51	7.45 10.77	37.2 53.8
	-15 -10	7.42	21.58 32.71	2.4 4.01	11.97 20.04	7 9.46	34.95 47.21	16.23 24.56	81.1 122 8
Contro of D/M	-5	18.03	52.43	6.25	31.23	10.6	52.92	33.26	166.2
	5	36.75	106.87	6.25	31.23	10.08	52.92	33.26	166.2
	10 15	37.45 30.59	108.92 88.97	4.01	20.04 11.97	9.46	47.21 34.95	24.56 16.23	122.8 81.1
Edge of R/W	20 25	19.87 12.31	57.77 35.82	1.46 0.93	7.28	4.71	23.51 15.93	10.77 7.45	53.8 37.2
	30	8.02	23.34	0.61	3.07	2.25	11.23	5.4	203
	40	4.05	11.76	0.3	1.51	1.26	6.31	3.17	15.8
	45 50	3.07	8.92 6.99		0.84	0.99	4.97	2.53	12.6
	55 60	1.93 1.58	5.61 4.61		0.65	0.66	3.3 2.76	1.72 1.45	8.5 7.2
	65 70	1.32	3.85 3.26		0.41	0.47	2.35	1.24	6.1 5.3
	75	0.96	2.8		0.00	0.35	1.75	0.93	4.6
	80 85	0.83	2.42			0.31	1.54 1.36	0.82	4.1 3.6
	90 95	0.64	1.87 1.67				1.21 1.09	0.65	3.2 2.9
	100 105	0.51	1.49				0.98	0.53	2.6
	110	0.42	1.21				0.81	0.44	2.1
	115	0.38	1.1				0.74	0.4	1.8
	125 130	0.32 0.29	0.92				0.62	0.34 0.31	1. 1.5
	135 140		0.78				0.53 0.5		1.4 1.3
	145		0.67				0.46		1.2
	155		0.59				0.43		1.1
	160 165		0.55				0.38		1.0 0.9
	170 175		0.48				0.34		0.9
	180 185		0.43				0.3		0.8
	190		0.38						0.7
	200		0.36						0.6
	205 210	<u> </u>	0.33 0.31						0.6
	215 220		0.3						0.5
	225								0.5
	230								0.4
	240 245								0.4
	250 255								0.4
	260								0.4
	265 270								0.3
	275 280								0.3
	285								0.3
	290								0.3
	300	1	1	1	1	1			0.

Project No. 3698488: Okanagan Transmission Reinforcement (OTR) Project Requestor Name: Hans Karow Information Request No: 1 - Outstanding from April 17/08 To: FortisBC Inc. Request Date: March 27, 2008 Response Date: April 22, 2008

1	Q12	Comparison chart of magnetic field levels from different appliance sources
2		For clear information of affected parties and in order to avoid
3		misunderstandings of EMF levels at various distances from sources
4		mentioned below, please supply a table in good readable format containing
5		the lowest,
6		mean, and
7		highest
8		reading of the appliances at distances from the sources:
9		10cm, 30cm, 50cm,1m, 2m, 3m, 5m, 10m, 25m, 50m, 100m, 150m, 200m,
10		250m, 300m:
11		a) electric shaver
12		b) electric toothbrush
13		c) can opener
14		d) hair dryer
15		e) light dimmer switch
16		f) non-digitale radio alarm clock
17		g) digitale radio alarm clock, and
18		h) projected to be upgraded lines
19		
20	A12	For item h) the following Karow Table A12, is provided for the proposed line
21		upgrade Alternative 1A.

Project No. 3698488: Okanagan Transmission Reinforcement (OTR) Project Requestor Name: Hans Karow Information Request No: 1 - Outstanding from April 17/08 To: FortisBC Inc. Request Date: March 27, 2008 Response Date: April 22, 2008

	Karow Table A12	
Alternative 1A – Distance	Average Case	Maximum Case
from Centre of Right of	(mG)	(mG)
Way (meters)		
0	7.54	37.63
1	7.48	37.33
2	7.30	36.46
5	6.25	31.23
10	4.01	20.04
25	0.93	4.62
50	0.17	0.84
100	0.02	0.12
150	0.01	0.04
200	0	0.02
250	0	0.01
300	0	0

1The NIEHS brochure EMF: Questions & Answers available at the following link2http://www.niehs.nih.gov/health/topics/agents/emf/docs/emf2002.pdf333-34 provides some of the above requested readings pertaining to a) electric4shaver, c) can opener, d) hair dryer, f and g) digital and analog clocks. This5brochure also includes readings of magnetic fields measured near other6sources for which readings were not requested.

Project No. 3698488: Okanagan Transmission Reinforcement (OTR) Project
Requestor Name: SOFAR & Wiltse Holdings
Information Request No: 1 - Outstanding from April 17/08
To: FortisBC Inc.
Request Date: March 27, 2008
Response Date: April 22, 2008

1 SOFAR/Wiltse IR1

- Q10.7 Please provide a similar rendering for each of the view lots in the
 Heritage Hills subdivision with the single pole, double circuit line in
 place.
- A10.7 Please see below the photographs of the existing line and renderings for four
 representative view lots in the Heritage Hills subdivision with the single pole,
 double circuit line in place. The proposed structure renderings are based on
 height of structures determined by preliminary design, final design may identify
 some change in height relative to existing structures.
- 10 SOFAR/Wiltse Attachment A10.7a is from 300 One Quail Place, Attachment
- 11 A10.7b is from 135 Big Horn Trail, Attachment A10.7c is from 161 Big Horn 12 Trail and Attachment A10.7d is from 260 Heritage Boulevard.

SOFAR/Wiltse Attachment A10.7a

SOFAR/Wiltse Attachment A10.7b

100

SOFAR/Wiltse Attachment A10.7c

SOFAR/Wiltse Attachment A10.7d

0

Project No. 3698488: Okanagan Transmission Reinforcement (OTR) Project
Requestor Name: SOFAR & Wiltse Holdings
Information Request No: 1 - Outstanding from April 17/08
To: FortisBC Inc.
Request Date: March 27, 2008
Response Date: April 22, 2008

1Q10.8Please provide a similar rendering at Heritage Boulevard in Heritage Hills2showing the double circuit section of lines 75 and 76 constructed on H-3frame wood poles, identify the height of those poles and explain why that4particular height was chosen.

- A10.8 Please find below rendering SOFAR/Wiltse Attachment A10.8 showing the
 double circuit section of 75 Line and 76 Line constructed on H-frame steel flat
 galvanized poles. The pole height, for physical strength, would require steel
 structures as opposed to wood. However the steel poles can be supplied with
 a "pre-weathered" finish which is a rust colour resembling wood.
- 10

The proposed structure renderings are based on structure height determined by 11 preliminary design. Final design may identify some change in height relative to 12 13 existing structures. The above ground height of the pole structure in the centre of the rendering is 37 meters (120 feet). The height of this structure is a 14 function of the higher elevation ground points for the adjacent structures north 15 and south. Per Appendix C page 11, (Exhibit B-1-2), this structure, L76 – 94, is 16 17 one that possible removal would be assessed during detailed design. However, if determined technically possible, this would increase pole height at 18 the adjacent structures, which may not be favoured by residents. 19

