



Dennis Swanson  
Director, Regulatory Affairs

**FortisBC Inc.**  
Suite 100 - 1975 Springfield Road  
Kelowna, BC V1Y 7V7  
Ph: (250) 717-0890  
Fax: 1-866-335-6295  
[electricity.regulatory.affairs@fortisbc.com](mailto:electricity.regulatory.affairs@fortisbc.com)  
[www.fortisbc.com](http://www.fortisbc.com)

October 21, 2011

**Via Email**

Ms. Alanna Gillis  
Acting Commission Secretary  
BC Utilities Commission  
Sixth Floor, 900 Howe Street, Box 250  
Vancouver, BC V6Z 2N3

Dear Ms. Hamilton:

***Re: FortisBC Inc. (FortisBC) Application for 2012 -2013 Revenue Requirements and Review of 2012 Integrated System Plan Responses to System Loss Information Requests***

Please find attached FortisBC's responses to the British Columbia Utilities Commission second round of Information Requests related to system losses.

If further information is required, please contact the undersigned at (250) 717- 0890.

Sincerely,

A handwritten signature in black ink, appearing to be "D Swanson", written over a horizontal line.

Dennis Swanson  
Director, Regulatory Affairs



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 1

1 **1.0 Reference: Gross System Losses**  
2 **Exhibit B-7, BCUC 1.1.1 – 1.1.4**  
3 **Forecasted Average Loss Rates**

4 1.1 What is the range of accuracy for the forecast average loss rates provided?

5  
6 **Response:**

7 Historical forecasting percentage errors for the gross loss rate over the 2001-2010 period have  
8 a mean of 1% and a standard deviation of 8.4%. Therefore, approximately 95% of the time the  
9 forecasting error for the loss rate will fall into the range  $(1\% - 2 \times 8.4\%, 1\% + 2 \times 8.4\%) = (-15.8\%,$   
10  $17.8\%)$ . It means that for 95% of the time, the loss rate will be between the range of  
11  $(0.842 \times \text{Expected Rate}, 1.178 \times \text{Expected Rate})$ . Below is the summary table for the forecasting  
12 range from 2012 to 2016:

13 **Table BCUC IR2 (Losses) 1.1**

**95% Range of Loss Rates**

Year	2012	2013	2014	2015	2016
Expected	8.82%	8.76%	8.69%	8.63%	8.55%
Low	7.43%	7.38%	7.32%	7.27%	7.21%
High	10.39%	10.32%	10.24%	10.16%	10.07%

14 Actual losses are heavily dependent on loads (weather) due to the I2R rule. If loads are higher  
15 than forecast by 5%, losses will be approximately 10% higher than the forecast loss rate.

16  
17

18 1.2 Are these forecast average loss rates used to calculate (or is a function of) other  
19 forecast values in the Application (i.e. purchase power)?

20

21 **Response:**

22 The expected loss rate is used to calculate the expected gross load, which drives the calculation  
23 of the expected power purchases and revenue requirements.

24 An example of the reduced rate impact from reducing the loss rate by 1% (i.e. from 8.8% to  
25 7.8%) was provided in the response to BCUC IR1 Q232.3.3 and is -0.6% in 2012 and -0.1% in  
26 2013.

27 1.2.1 If so, please identify which calculations and demonstrate the impact of the  
28 forecasted average loss rates on these figures.



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 2

1

2 **Response:**

3 Please refer to the response BCUC IR2 (Losses) Q1.2 above.

4

5

6 1.3 If the Company is forecasting the average losses to “flatten out” as indicated in  
7 the IR response, why do the data points supplied by FortisBC have a positive  
8 slope?

9

10 **Response:**

11 Please refer to the responses to BCUC IR1 (Losses) Q1.1 and BCUC IR1 (Losses) Q1.2. In  
12 addition, the Company notes that the forecast loss rate of 8.82% declines to 8.55% by 2016 and  
13 therefore the slope is not positive as stated in the question.

14

15

16 1.4 As the forecasted average losses shown in the Application do not include the  
17 estimated impact of the OTR project, please adjust and file an update of all  
18 calculations and amounts in the Application that use the revised values.

19

20 **Response:**

21 Changes to losses do not affect forecast sales, only forecast power purchase expense.

22 As described in BCUC IR1 (Losses) Q1.3, the 2012-13 RRA did not include any loss reduction  
23 benefit from the completion of the OTR project nor was the loss percentage increased as a  
24 result of sales growth. Adjusting for both these factors, the Company has estimated a net  
25 reduction in the forecast losses from the Application of 12.2 GWh in 2012 and 9.5 GWh in 2013  
26 as shown in Table BCUC IR2 (Losses) 1.4 below.

27 A reduction to forecast losses of 10.0 kWh annually beginning in 2014 is also proposed, as  
28 explained in point 6 of the Load Growth Loss Adjustment section below.



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 3

1

**Table BCUC IR2 (Losses) 1.4a**

	OTR Loss Reduction	Load Growth Loss Increase	Net Loss Reduction
	(GWh)		
2012	(18.1)	5.9	(12.2)
2013	(19.6)	10.1	(9.5)

2 The details of these calculated amounts are given below.

3 **OTR Loss Reduction**

4 The calculation of the reduction of energy losses due to the OTR project in GWh/year is  
 5 performed as follows and is summarized in Table BCUC IR2 (Losses) 1.4b below:

- 6 1. The loss at peak in kW for 2010 is determined from a power flow simulation model, using  
 7 the Power System Simulation for Engineering (PSS®E) software and the 2010 Winter  
 8 Peak WECC base case;
- 9 2. The loss at peak for 2011-13 is calculated from (1) by applying the loss growth rate of  
 10 8%. The rate of 8% is the square of the load growth rate in the North and South  
 11 Okanagan;
- 12 3. The average loss for each year is calculated from (2) by applying the Loss Load Factor  
 13 (LLF) of 31.5%<sup>1</sup>;
- 14 4. The annual energy loss is calculated by multiplying (3) by 8,760 hours;
- 15 5. Column “DIFF” shows the difference in pre-OTR and post-OTR annual energy loss in  
 16 GWh;
- 17 6. The values from (5) are multiplied by the “project in service” percentage for each year to  
 18 provide the energy loss savings. The “project in service” percentage is a combination of  
 19 the loss saving project portions (the 230 kV lines) and the number of months in service  
 20 per year; and
- 21 7. The values from (6) are reduced by 50% or 0.6 GWh of the 2010 loss savings to account  
 22 for the fact that the average losses from 2009 and 2010 were used in the Application.

---

<sup>1</sup> The **Loss Load Factor (LLF)** is computed from the empirical formulas: **LLF = 0.3 L<sub>f</sub> + 0.7 L<sub>f</sub><sup>2</sup>** for urban areas and **LLF = 0.16 L<sub>f</sub> + 0.84 L<sub>f</sub><sup>2</sup>** for rural areas, where L<sub>f</sub> is the Load Factor (ratio of average kW to peak kW). In this analysis a combined urban/rural formula was used as follows: **LLF = 0.2 L<sub>f</sub> + 0.8 L<sub>f</sub><sup>2</sup>**. [Ref. A.S. Pabla, *Electric Power Distribution*].



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 4

1

**Table BCUC IR2 (Losses) 1.4b**

Loss Growth Rate	8.0%	Load Factor (LF)	51.5%	Loss Load Factor (LLF)	31.5%
------------------	------	------------------	-------	------------------------	-------

	PRE-OTR			POST-OTR			DIFF	PROJECT IN SERVICE	ENERGY LOSS SAVINGS	ENERGY LOSS SAVINGS w 2010 ADJUSTMENT
	Loss at Peak kW	Average Loss kW	Energy Loss GWh	Loss at Peak kW	Average Loss kW	Energy Loss GWh	GWh	%	GWh	GWh
2010	30,900	9,741	85.3	25,100	7,913	69.3	16.0	8	1.3	N/A
2011	33,372	10,521	92.2	27,108	8,546	74.9	17.3	87	15.1	14.5
2012	36,042	11,362	99.5	29,277	9,230	80.9	18.7	100	18.7	18.1
2013	38,925	12,271	107.5	31,619	9,968	87.3	20.2	100	20.2	19.6

2

3 **Load Growth Loss Adjustment**

4 The calculation of the increase of energy losses due to the increased loss rate caused by load  
 5 growth in GWh/Year is performed as follows and is summarized in Table BCUC IR2 (Losses)  
 6 1.4c below:

- 7 1. The load growth rate must use the sales growth rate since the correct loss growth rate is  
 8 the square of the load growth rate;
- 9 2. The assumed loss growth rate in the Application before AMI adjustments is flat and  
 10 therefore grows at the same percentage as sales grow;
- 11 3. The correct loss growth rate is that losses grow at a rate that is the square of the load  
 12 growth rate. For example, if loads grow by 10%, all else being equal, losses will grow by  
 13  $1.1 * 1.1 = 1.21$  or by 21%;
- 14 4. Losses before AMI must be used since AMI is not changing the actual load for the first  
 15 several years;
- 16 5. The corrected losses and the required adjustment to gross load; and
- 17 6. All things being equal, the adjustment column will continue to grow in size. However, it  
 18 is assumed that various smaller upgrade projects that occur from time to time will result  
 19 in a flat 10 GWh reduction for 2014 onward.



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 5

1

**Table BCUC IR2 (Losses) 1.4c**

	<b>Load Growth Rate</b>	<b>Assumed Loss Growth Rate</b>	<b>Correct Loss Growth Rate</b>	<b>Forecast Losses before AMI</b>	<b>Corrected Losses</b>	<b>Loss Adjustment (GWh)</b>	<b>Combined OTR Loss Adjustment (GWh)</b>
<b>2010</b>	-3.6%				294.2		
<b>2011</b>	2.37%	2.37%	4.8%	305.8	308.2	2.5	N/A
<b>2012</b>	1.08%	1.08%	2.2%	309.1	314.9	5.9	(12.2)
<b>2013</b>	1.24%	1.24%	2.5%	312.6	322.8	10.1	(9.5)
<b>Future</b>							(10.0)


2 The impact of this reduction in losses to 2012 and 2013 Power Purchase Expense and the  
 3 resulting rate impacts will be included in the Evidentiary Update to the 2012-13 RRA to be filed  
 4 on or before November 2, 2011 (please see the response to BCUC IR2 Q1.1)

5  
6

7 **2.0 Reference: Losses**  
 8 **Exhibit B-7, BCUC 1.1.2.1**  
 9 **System Loss Composition**

10 FortisBC responded that it “is unable to provide the requested [loss composition] data as  
 11 the Company has insufficient information to apportion total system losses in this manner.  
 12 Currently, the Company only has knowledge of the total system losses and these are  
 13 calculated by subtracting the total energy billed in a given interval from the total energy  
 14 generated or imported in the same interval. Additional metering infrastructure such as  
 15 that proposed in the Advanced Metering Initiative project would be required to support  
 16 the collection of loss data at this granularity.”

17 During the FortisBC 2010 Annual Review and 2011 Revenue Workshop, FortisBC  
 18 provided its average annual energy thefts in kWhs on slide 2 of the Revenue Protection  
 19 presentation that was filed as Exhibit B-5 in that proceeding and copied below:



1  
2  
3  
4  
5  
6

2.1 Please reconcile the following table with estimated figures in GWhs. The three lines of losses provided (Lines 1-3 below) appear to add up to the total line indicating that unaccounted for energy thefts plus meter inaccuracies equal zero, which is contradictory to the slide presentation above. Please explain and provide an updated table. Update other parts of the Application as required.

	Type of System Loss (Average Annual GWh)	2006	2007	2008	2009	2010	2012	2013	Total
1	Losses in the transmission and distribution system	313	310	272	258	227			
2	Company use	12	13	11	12	12			
3	Losses due to wheeling through the BC Hydro system	40	23	30	51	41			
4	Unaccounted-for energy (meter inaccuracies)								
5	Unaccounted-for energy (theft) <i>(source: Exhibit B-5 in FortisBC 2010 Annual Review and 2011 RRA)</i>		<b>80.12</b>	<b>114.80</b>	<b>118.83</b>	<b>93.02</b>			
	Total (as provided in response to Table BCUC IR1 2.1)	364 ?	346 ?	313 ?	321 ?	280 ?	306 ?	309 ?	310 ?

7



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 7

1 **Response:**

2 FortisBC notes that kWh were incorrectly converted to GWh in the table provided above. For  
3 example, in 2007, 80,119 kWh per equals 0.080199 GWh per site or 1.7 GWh total. This  
4 amount is a small portion of total losses.

5 In the response to BCUC IR1 (Losses) Q2.1, FortisBC did not assume that unaccounted for  
6 energy plus meter inaccuracies equaled zero – the Company assumed that unaccounted for  
7 energy plus meter inaccuracies were included in the Line 1 (Losses in the transmission and  
8 distribution system).

9 FortisBC also notes that the theft figures provided in Exhibit B-5 in FortisBC 2010 Annual  
10 Review and 2011 RRA represents the estimated amount of *detected* theft and not an estimate  
11 of the total amount of theft that exists.

12  
13

14 2.2 Please provide an updated Table BCUC IR1 2.2 and update relevant parts of the  
15 Application as required.

16

17 **Response:**

18 An update to Table BCUC IR1 2.2 is not required since the total value of system losses has not  
19 changed.

20  
21

22 2.3 Please attempt to separate transmission losses from distribution losses for each  
23 year in the table above, even if only on a modeled basis.

24

25 **Response:**

26 A modeled separation of total energy losses into approximate transmission and distribution  
27 components is provided below.





FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 8

1 **Table BCUC IR2 (Losses) 2.3 - Approximate Transmission and Distribution Energy**  
2 **Losses**

	2007	2008	2009	2010
Energy Sales GWh	3,064	3,087	3,157	3,044
T&D Losses GWh	310	272	258	227
Transmission Losses GWh	88	77	73	64
Distribution Losses GWh	222	195	185	163

3  
4  
5  
6  
7  
8  
9

2.4 Please identify which portions of the transmission system FortisBC has the ability to directly meter losses. For instance, which substations, lines or groups of lines and substations, can be “ring-fenced” by meters that are capable of metering total energy?

10  
11

**Response:**

12 Almost all transmission lines and substations can be “ring fenced” by meters to provide metered  
13 energy losses. However, there are some exceptions at various locations in the service area  
14 where stations (primarily transmission customer interconnections) are not equipped with  
15 appropriate metering. Through coincident time-stamped meter readings, transmission system  
16 energy losses could be calculated, however manual corrections would need to be made for the  
17 transmission customers mentioned above. In addition, although the raw energy data is available  
18 for the most part, database queries and reconciliation software would need to be developed and  
19 tested to implement these loss calculations.

20 Note that a similar exercise to determine distribution system losses is not possible without the  
21 installation of Advanced Metering Infrastructure.



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 9

1   **3.0   Reference:   System Planning Forecasts**  
2                                   **Exhibit B-7, BCUC 1.6.2, Table BCUC IR1.6.2; BCUC 1.229.2**  
3                                   **1-in-20 Peak Forecast**

4           3.1   As the industry practice appears to more consistently use a 1-in-10 risk level,  
5                   please provide Table BCUC IR1.6.2 showing the summer and winter “1-in-10”  
6                   peak load forecasts, and provide the comparison with the “1-in-20” results.

7  
8   **Response:**

9   FortisBC offers the following clarifications with respect to the 1-in-20 peak forecast:

- 10           1. The forecast is not used for resource planning (i.e. for power purchases);
- 11           2. The forecast is not used directly for system capital planning.
- 12           3. The forecast is used only for benchmarking the existing distribution planning forecast.  
13                   The distribution planning forecast does not inherently contain a quantifiable risk index  
14                   (as it is constructed from the “bottom up” using historical, individual feeder load data). By  
15                   comparing the 1-in-20 forecast to the distribution planning forecast, FortisBC is then able  
16                   to confirm that the distribution planning forecast (and hence system infrastructure) can  
17                   accommodate potential load increases due to reasonably extreme weather variations.
- 18           4. All capital projects were driven solely by the distribution planning forecast; no project  
19                   timing changes resulted from the use of the 1-in-20 forecast.

20   Notwithstanding the above, FortisBC also does not agree that industry practice is standardizing  
21   around a specific risk index for system planning purposes. There are currently no standards,  
22   mandatory or other, that prescribe the risk level and confidence bands of a load forecast. Local  
23   conditions in the economy and weather vary significantly in different jurisdictions, making the  
24   application of uniform risk standards impractical. For example, a 95% confidence band will be  
25   wider in jurisdiction A vs. B, if weather patterns in A are more variable than in B. Several utilities  
26   (Bonneville Power, PacifiCorp, ISO New England and others) compute confidence bands for  
27   90% and 95% confidence (1-in-10 and 1-in-20 risk levels). BC Hydro employs Monte Carlo  
28   methods to compute a 90% confidence band, indicating there is a 10% probability that the  
29   actual peak load will exceed the forecast peak load in a particular year. Similarly, the PJM  
30   interconnection employs a 90% confidence level. A large geographic jurisdiction, such as PJM,  
31   Bonneville, ISONE, will generally have a lesser variance due to extreme weather, as non-  
32   uniform weather conditions will mitigate the total effect. Smaller areas, such as FortisBC, are  
33   exposed to a greater relative weather risk. The objective of the 1-in-20 load forecast at FortisBC  
34   is to provide system planners with a benchmark level that quantifies the risk of the transmission  
35   plan. Transmission adequacy is extremely important, as shortages in transmission cannot be  
36   mitigated in the short term except with customer outages.



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 10

1 Please find the requested tables below.

2 **Table BCUC IR2 (Losses) 3.1**


	<b>1-in-20</b>		<b>1-in-10</b>		<b>1-in-10 vs. 1-in-20</b>	
	<b>Year that sets the peak</b>					
	1998	1990	2007	2004		
	SUMMER PEAK (MW)	WINTER PEAK (MW)	SUMMER PEAK (MW)	WINTER PEAK (MW)	SUMMER PEAK (MW)	WINTER PEAK (MW)
<b>2011</b>	652	843	636	842	-15	-1
<b>2012</b>	661	856	645	855	-15	-1
<b>2013</b>	669	869	654	867	-16	-2
<b>2014</b>	678	880	662	876	-16	-4
<b>2015</b>	685	890	668	882	-16	-8
<b>2016</b>	688	895	671	887	-17	-8
<b>2017</b>	692	902	675	895	-17	-7
<b>2018</b>	697	910	680	902	-17	-8
<b>2019</b>	703	918	685	910	-17	-8
<b>2020</b>	708	926	691	918	-18	-8
<b>2021</b>	714	935	696	927	-18	-8
<b>2022</b>	720	943	702	935	-18	-9
<b>2023</b>	726	951	708	943	-18	-8
<b>2024</b>	732	960	713	951	-18	-9
<b>2025</b>	738	969	719	960	-19	-9
<b>2026</b>	744	977	725	968	-19	-9
<b>2027</b>	750	986	731	977	-19	-9
<b>2028</b>	756	995	737	985	-19	-9
<b>2029</b>	763	1004	743	994	-20	-10
<b>2030</b>	769	1013	749	1003	-20	-10
<b>2031</b>	775	1022	755	1012	-20	-10
<b>2032</b>	782	1031	761	1021	-20	-10
<b>2033</b>	788	1041	767	1031	-21	-10
<b>2034</b>	795	1051	774	1040	-21	-10
<b>2035</b>	802	1061	780	1050	-21	-11
<b>2036</b>	808	1071	787	1060	-21	-11
<b>2037</b>	815	1081	794	1071	-22	-11
<b>2038</b>	823	1092	801	1081	-22	-11
<b>2039</b>	830	1103	808	1091	-22	-11
<b>2040</b>	837	1113	815	1102	-23	-11

1           3.2     Please provide the tables and figures in BCUC 1.229.2 for the “1-in-10” risk level,  
2                     and provide the comparisons to the “1-in-20” risk level results. Please also  
3                     provide the results in electronic format.

4     **Response:**

5     Please find the answer below. The results are also provided in an electronic Excel file titled  
6     “BCUC Losses IR2 Q3.2.xlsx”.


7   **Figure BCUC IR2 (Losses) 3.2a**



8

9

**Figure BCUC IR2 (Losses) 3.2b**



10



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 12

1

**Table BCUC IR2 (Losses) 3.2**

Actual/Forecast Peaks (MW)				1-in10 vs 1-in-20					
Year	Annual Avg.	Winter	Summer	1-in-20 Winter	1-in-20 Summer	1-in-10 Winter	1-in-10 Summer	Winter	Summer
1990	437	623	396						
1991	439	530	400						
1992	443	640	420						
1993	472	600	415						
1994	476	642	469						
1995	479	667	449						
1996	502	651	447						
1997	468	631	446						
1998	471	628	483						
1999	459	548	453						
2000	469	616	473						
2001	483	576	486						
2002	501	555	515						
2003	502	715	523						
2004	516	708	511						
2005	525	675	508						
2006	547	711	548						
2007	538	659	561						
2008	541	746	532						
2009	552	700	553						
2010	531	707	554						
2011	550	772	586	843	652	842	636	-1	-15
2012	557	788	598	856	661	855	645	-1	-15
2013	565	805	611	869	669	867	654	-2	-16
2014	572	821	623	880	678	876	662	-4	-16
2015	577	835	634	890	685	882	668	-8	-16
2016	579	846	642	895	688	887	671	-8	-17
2017	582	856	650	902	692	895	675	-7	-17
2018	587	868	658	910	697	902	680	-8	-17
2019	591	879	667	918	703	910	685	-8	-17
2020	595	891	676	926	708	918	691	-8	-18
2021	600	903	685	935	714	927	696	-8	-18
2022	605	915	695	943	720	935	702	-9	-18
2023	610	927	703	951	726	943	708	-8	-18
2024	614	940	713	960	732	951	713	-9	-18
2025	619	952	722	969	738	960	719	-9	-19
2026	624	964	731	977	744	968	725	-9	-19
2027	629	977	741	986	750	977	731	-9	-19
2028	634	989	750	995	756	985	737	-9	-19
2029	639	1,002	760	1,004	763	994	743	-10	-20
2030	644	1,014	769	1,013	769	1,003	749	-10	-20

2



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 13

1           3.3     Please identify those projects and parts of the Application that would need to be  
2                   revised because of the changed “1-in-10” summer and winter peak load  
3                   forecasts.

4     **Response:**

5     As stated in the response to BCUC IR2 (Losses) Q3.1 above, the “1-in-20” forecast was used  
6     only for benchmarking purposes, to provide a quantitative assessment of the risk of the  
7     Distribution Load Forecast, and as a consistency check against the Resource Planning Load  
8     Forecast. It has not been used directly to determine the need or timing of specific capital  
9     projects and the use of a “1-in-10” forecast would not impact either the Long Term Capital Plan  
10    or customer rates.

11  
12

13   **4.0     Reference:   Energy Theft**  
14                   **Exhibit B-7, BCUC 1.1.4, 1.3.1; BCOAPO 1.8.1**  
15                   **AMI Impact**

16           4.1     In responses to BCUC 1.3.1, FortisBC states that “AMI technology will enable  
17                   FortisBC to identify more comprehensively both the incidence and value of  
18                   energy theft.” Given that the above slide presentation appears to suggest that  
19                   FortisBC is already able to specifically identify energy thefts by year, is there still  
20                   a need for AMI?

21

22   **Response:**

23   Yes. AMI is expected to significantly enhance existing theft detection efforts and results.

24  
25

26           4.2     The previous slide provided by FortisBC indicates that energy theft losses are  
27                   approximately 100 GWh/year, what is the estimated incremental benefit provided  
28                   by AMI in GWhs and dollars saved.

29

30   **Response:**

31   As explained in the response to BCUC IR2 (Losses) Q2.1 above, the estimate of total energy  
32   theft is not 100 GWh a year.



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 14

1 At this time, the Company estimates total theft at approximately 42 GWh a year. The estimated  
 2 AMI GWh benefit is given in more detail in the response to BCUC IR1 Q231.4. The estimated  
 3 residential rate is only available through 2016. Estimated AMI benefits from reduced energy  
 4 theft are presented in the table below.

5 **Table BCUC IR2 (Losses) 4.2**

	<b>AMI Sales Increase</b>	
	<b>MWh</b>	<b>\$000s</b>
<b>2012</b>	-	-
<b>2013</b>	2,286	245,070
<b>2014</b>	4,662	528,753
<b>2015</b>	7,132	901,104
<b>2016</b>	9,694	1,287,204

6  
7  
8

9 4.3 Please explain why the average losses do not decline even with the  
 10 implementation of AMI.

11 **Response:**

12 The expected losses are, in fact, forecast to decline with the implementation of AMI. Please  
 13 refer to BCUC IR1 (Losses) 1.4 for further information. A summary of forecast loss rates is  
 14 found below.

15 **Table BCUC IR2 (Losses) 4.3**

2012	2013	2014	2015	2016
8.82%	8.76%	8.69%	8.63%	8.55%

16  
17

18 4.4 In response to BCUC 1.1.4, FortisBC appears to indicate that gross losses are  
 19 estimated at 312.6 GWh, while information provided in the above presentation  
 20 slide indicates power thefts to be approximately 100 GWh. Please explain the  
 21 difference.

22 **Response:**

23 As stated in response to BCUC IR2 (Losses) Q4.2, the current best estimate the Company has  
 24 of total losses due to theft is 42 GWh. This is only a small portion of the total system losses that  
 25 are mainly resistance losses in the system.



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 15

1   **5.0   Reference:   Energy Theft**  
2                                   **Exhibit B-7, BCUC 1.1.4, 1.3.1; BCOAPO 1.8.1**  
3                                   **AMI Impact**

4           5.1   Please provide FortisBC’s estimate of the current amount of energy theft, and the  
5                   effect by year of the AMI project on the amounts of a) remaining stolen electricity,  
6                   b) electricity converted to billed sales, and c) reduction in the amount of used  
7                   electricity, and the corresponding effects on losses.

8  
9   **Response:**

10 Please refer to the response to BCUC IR1 Q231.4 for the requested information. The  
11 Company’s current best estimate of the total theft is 42 GWh annually. Total increased sales  
12 peak at 12 GWh in 2017 and then decline to zero by 2022. Total loss reduction in 2022 is 13  
13 GWh and slowly increases with load growth thereafter.

14  
15

16           5.2   Please explain why the gross residential load is not expected to decline as  
17                   electricity theft is reduced because of AMI. Does FortisBC expect that all existing  
18                   energy theft will be converted to sales, and if so why? Why does FortisBC not  
19                   expect the existing usage via stolen electricity to decline, when converted to  
20                   billed electricity? If electricity usage will decline, please revise all calculations in  
21                   the Application to reflect this decline.

22

23   **Response:**

24 FortisBC does expect existing energy theft to be converted to sales, which is offset by a  
25 commensurate decrease in losses for the period 2013 – 2017, resulting in no change to gross  
26 load. FortisBC does expect that detected incidences of electricity theft will eventually culminate  
27 in reduced residential sales from 2018 to 2022, as explained and tabulated in the response to  
28 BCUC IR1 Q231.4. By 2022 there will no longer be any positive impact to sales due to  
29 detection of electricity theft but the loss savings will continue, thereby resulting in reduced gross  
30 load, which has been taken into account in the load forecast.

31  
32





FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 16

1 **6.0 Reference: Data Retention**  
2 **Exhibit B-7, BCUC 1.228.1.1**

3 6.1 Please describe FortisBC's policy for electric system data retention. Is data prior  
4 to 2004 available?

5  
6 **Response:**

7 FortisBC interprets this question as referring to distribution substation load data (which was the  
8 subject of the original information request). FortisBC has no formal policy related to this data. In  
9 general, information and electronic data is retained for the period that it is considered relevant.  
10 Detailed substation load data prior to 2004 is not readily available in an electronic form.  
11 Moreover, as discussed in the response to BCUC IR1 Q228.1.2 this data is no longer  
12 considered useful as the electric system has been reconfigured multiple times since that date.  
13 Many new substations and feeders have been added and old substations have been retired.  
14 Tracking the movement of distribution loads from source to source over a long interval is  
15 impractical. Thus, a simple comparison of recent substation actual load data to that from many  
16 years ago is not meaningful.

17  
18

19 **7.0 Reference: Line Losses**  
20 **Exhibit B-7, BCUC 1.232.2**  
21 **Mitigating losses**

22 FortisBC indicates that reduction in system losses has been an ancillary benefit from  
23 many recent system upgrade projects. Loss reduction results from an increase in the  
24 supply voltage or by the installation of additional transformation capacity.

25 FortisBC also identifies several projects in the five-year timeframe that are all expected  
26 to result in some reduction in system losses.

27 7.1 Please explain then why is the Company only "forecasting losses to flatten out" in  
28 the test period (as indicated in responses to BCUC 1.1.2)?

29

30 **Response:**

31 Future transmission and distribution losses, as a percentage of total energy, are impacted by  
32 various factors, including:

- 33 1. Several projects have some loss reduction benefits, as stated in the question.



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 17

1           2. Load growth. This impact can be substantial, as the increase in losses is proportional to  
2           the square of the increase in energy flows.

3           The combined effect of (1) and (2) can be a “flattening out” of losses in the test period.

4           Please refer to the response to BCUC IR2 (Losses) Q1.4 for a discussion of the Company’s  
5           proposed downward loss adjustments for 2012 and 2013 that were presented in the response to  
6           BCUC IR1 (Losses) Q1.3.

7  
8  
9           FortisBC indicates that “losses will increase (in percentage terms) as load increases,” (in  
10           BCUC 1.1.3) and “load growth increases losses over time” (in BCUC 1.232.2).

11           7.2     Load growth is a function of both customer growth and use per customer. Does  
12           FortisBC agree that DSM measures affect use per customer to some degree? If  
13           so, then please explain how it is possible that any potential reduction in losses  
14           are all offset by load growth?

15  
16           **Response:**

17           The question is not clear to the Company.  
18           The impact of DSM on average use per customer is not relevant since system losses are not a  
19           direct function of the average use per customer, but of the total demand of all customers. It is  
20           this total system requirement that must be transported through the system to the customer.  
21           Since the overall system load is growing, losses will increase as well.

22  
23  
24           **8.0     Reference:    Line Losses**  
25                               **Exhibit B-7, BCUC 1.232.3**  
26                               **Historical losses**

27           In response to BCUC 1.232.3, FortisBC indicates that it is “unable to provide the  
28           requested data as the company has insufficient information to apportion total system  
29           losses between the various causes...”

30           8.1     Given the slide presentation previously provided on power thefts, it appears that  
31           FortisBC is able to indentify losses due to energy thefts. Please revise your  
32           response to include other causes of energy loss by year for the period 2000-  
33           2010.



FortisBC Inc. (FortisBC or the Company) Application for 2012 – 2013 Revenue Requirements and Review of 2012 Integrated System Plan	Submission Date: October 21, 2011
Response to British Columbia Utilities Commission (BCUC or the Commission) Information Request (IR) No. 2 (Losses)	Page 18

- 1
- 2 **Response:**
- 3 The current estimate of total theft is 42 GWh a year on a forecast basis. The actual number is
- 4 highly uncertain and this estimate is based on information from BC Hydro. The Company is not
- 5 able to determine what theft may have been over the 2000 to 2010 period. Please refer to the
- 6 response to BCUC IR2 (Losses) Q2.1 for further information.